



© 2010 Lennox Industries Inc.
Dallas, Texas, USA

HEAT PUMP UNITS

TP Technical
Publications
Litho U.S.A.

506907-01
10/2011

SUPPLEMENT

SUPPLEMENT TO T-CLASS™ TPA SERIES (7.5 AND 10-TON) INSTALLATION INSTRUCTION 506148-01

Defrost Control Time Pins (P1)

Each timing pin selection provides a different accumulated compressor run time period for one defrost cycle. This time period must occur before a defrost cycle is initiated. The defrost interval can be adjusted to 30 (T1), 60 (T2), or 90 (T3) minutes. The maximum defrost period is 14 minutes and cannot be adjusted.

NOTE — Defrost control part number is listed near the P1 timing pins.

- Units with defrost control **100269-02**: Factory default is 60 minutes.
- Units with defrost control **100269-04**: Factory default is 90 minutes

If the timing selector jumper is missing, the defrost control defaults to a 90-minute defrost interval.

