



# Guide Specifications

**MERIT® Series**

**CBX25UH**

**R-410A – Upflow/Horizontal**

**March 7, 2013**



**Note:** This specification is for Lennox Industries **CBX25UH, CBX Series Air Handlers**. Revise specification section number and title below to suit project requirements, specification practices and section content. Refer to CSI *MasterFormat* for other section numbers and titles.

This specification utilizes the Construction Specifications Institute (CSI) *Manual of Practice*, including *MasterFormat™*, *SectionFormat™* and *PageFormat™*. Optional text and text requiring a decision is indicated by bolded brackets [ ]; delete text not required in final copy of specification. Specifier Notes typically precede specification text; delete notes in final copy of specification. Trade/brand names with appropriate symbols typically are used in Specifier Notes; symbols are not used in specification text. Metric conversion, where used, is soft metric conversion.

---

## FAN COIL UNITS & UNIT VENTILATORS

SECTION 23 82 19

SECTION 23 82 23

### PART 1 - GENERAL

#### 1.1 SECTION INCLUDES

- A. Upflow/Horizontal Blower Coil Units

Specifier Note: Revise paragraph below to suit project requirements. Add section numbers and titles per CSI *MasterFormat* and specifier's practice.

#### 1.2 RELATED SECTIONS

Specifier Note: Article below may be omitted when specifying manufacturer's proprietary products and recommended installation. Retain Reference Article when specifying products and installation by an industry reference standard. If retained, list standard(s) referenced in this section. Indicate issuing authority name, acronym, standard designation and title. Establish policy for indicating edition date of standard referenced. Conditions of the Contract or Division 1 References Section may establish the edition date of standards. This article does not require compliance with standards, but is merely a listing of references used. Article below should list only those industry standards referenced in this section. Retain only those reference standards to be used within the text of this Section. Add and delete as required for specific project.

#### 1.3 REFERENCES

- A. Air-Conditioning, Heating and Refrigeration Institute (AHRI):
  - 1. AHRI 210/240 Unitary Air-Conditioning and Air-Source Heat Pump Equipment
- B. Servicing Safety Standards:
  - 1. National Electric Code (NEC)
  - 2. Canadian Electric Code (CEC)
  - 3. ETL certified for U.S. and Canada
- C. ISO 9001, units manufactured to quality standard

Specifier Note: DOE rating is for units with optional electric heater.

- D. [Department of Energy (DOE), rated in accordance to test procedures]

Specifier Note: FTCLabeling regulations are for units with optional electric heater.

- E. [Federal Trade Commission (FTC), labeling regulations]

Specifier Note: Article below should be restricted to statements describing design or performance requirements and functional (not dimensional) tolerances of a complete system. Limit descriptions to

composite and operational properties required to link components of a system together and to interface with other systems.

#### 1.4 PERFORMANCE REQUIREMENTS

- A. Air Handler: [1.5-,2-,2.5-,3-,3.5-,4-,5-] tons
- B. Electrical Characteristics:
  - 1. 60 Hz
  - 2. 208/230 V
  - 3. 1-phase

Specifier Note: Article below includes submittal of relevant data to be furnished by Contractor before, during or after construction. Coordinate this article with Architect's and Contractor's duties and responsibilities in Conditions of the Contract and Division 1 Submittal Procedures Section.

#### 1.5 SUBMITTALS

- A. General: Submit listed submittals in accordance with Conditions of the Contract and Division 1 Submittal Procedures
- B. Product Data: Submit product data for specified products
- C. Shop Drawings:
  - 1. Submit shop drawings in accordance with Section [01 33 00 - Submittal Procedures]
  - 2. Indicate:
    - a. Equipment, piping and connections, together with valves, strainers, control assemblies, thermostatic controls, auxiliaries and hardware and recommended ancillaries which are mounted, wired and piped ready for final connection to building system, its size and recommended bypass connections.
    - b. Piping, valves and fittings shipped loose showing final location in assembly
    - c. Control equipment shipped loose, showing final location in assembly
    - d. Field wiring diagrams
    - e. Dimensions, internal and external construction details, installation clearances, recommended method of installation, sizes and location of mounting bolt holes.
    - f. Detailed composite wiring diagrams for control systems showing factory installed wiring and equipment on packaged equipment or required for controlling devices or ancillaries, accessories, controllers.
- D. Quality Assurance:
  - 1. Test Reports: Certified test reports showing compliance with specified performance characteristics and physical properties
  - 2. Certificates: Product certificates signed by manufacturer certifying materials comply with specified performance characteristics and criteria and physical requirements
  - 3. Manufacturer's Instructions: Manufacturer's installation instructions

Specifier Note: Coordinate paragraph below with Part 3 Field Quality Requirements Article herein. Retain or delete as applicable.

- E. Manufacturer's Field Reports: Manufacturer's field reports specified herein

- F. Closeout Submittals: Submit the following:
  - 1. Warranty: Warranty documents specified herein
  - 2. Operation and Maintenance Data: Operation and maintenance data for installed products in accordance with Division 1 Closeout Submittals (Maintenance Data and Operation Data) Section. Include methods for maintaining installed products and precautions against cleaning materials and methods detrimental to finishes and performance. Include names and addresses of spare part suppliers.
  - 3. Provide brief description of unit, with details of function, operation, control and component service.
  - 4. Commissioning Report: Submit commissioning reports, report forms and schematics in accordance with Section [01 81 00 – Commissioning]

## 1.6 QUALITY ASSURANCE

- A. Qualifications:
  - 1. Installer experienced in performing work of this section who has specialized in installation of work similar to that required for this project

## 1.7 DELIVERY, STORAGE & HANDLING

- A. General: Comply with Division 1 Product Requirements
- B. Ordering: Comply with manufacturer's ordering instructions and lead time requirements to avoid construction delays
- C. Packing, Shipping, Handling and Delivery:
  - 1. Deliver materials in manufacturer's original, unopened, undamaged containers with identification labels intact
  - 2. Ship, handle and unload units according to manufacturer's instructions
- D. Storage and Protection:
  - 1. Store materials protected from exposure to harmful weather conditions
  - 2. Factory shipping covers to remain in place until installation

Specifier Note: Coordinate article below with Conditions of the Contract and Division 1 Closeout Submittals (Warranty).

## 1.8 WARRANTY

- A. Project Warranty: Refer to Conditions of the Contract for project warranty provisions
- B. Manufacturer's Warranty: Submit, for Owner's acceptance, manufacturer's standard warranty document executed by authorized company official. Manufacturer's warranty is in addition to, and not a limitation of, other rights Owner may have under Contract Documents.

Specifier Note: Coordinate paragraph below with manufacturer's warranty requirements.

- C. Warranty: Commencing on Date of Installation

Specifier Note: Refer to Lennox Equipment Limited Warranty certificate included with equipment for

details.

1. All Covered Components: 1 year limited (nonresidential applications).

## **PART 2 - PRODUCTS**

Specifier Note: Retain article below for proprietary method specification. Add product attributes, performance characteristics, material standards and descriptions as applicable. Use of such phrases as “or equal” or “or approved equal” or similar phrases may cause ambiguity in specifications. Such phrases require verification (procedural, legal and regulatory) and assignment of responsibility for determining “or equal” products.

### **2.1 UPFLOW/HORIZONTAL/MULTI-POSITION AIR HANDLER UNITS**

- A. Manufacturer: Lennox Industries
  1. Contact: 2140 Lake Park Blvd., Richardson, TX 75080; Telephone: (800) 453-6669; Web site: [www.lennoxcommercial.com](http://www.lennoxcommercial.com)
- B. General:
  1. Air-Flow
    - a. Upflow/Horizontal
    - b. [1.5-] [2-] [2.5-][3-][3.5-][4-][5-] nominal tonnage
- C. Proprietary Products/Systems:
  1. Cabinet:
    - a. Heavy gauge galvanized steel
    - b. Pre-painted finish
    - c. Insulated with foil faced fiberglass insulation
    - d. Removable panels for complete service access
    - e. Filter access door for easy filter replacement
    - f. Low Leakage
    - g. Shipped in one piece
    - h. Drain Pans:
      1. Knock-outs for drain connections for Upflow(left and right) and Horizontal applications
      2. Anti-Microbial Coating Dual Position
  2. Refrigerant System:
    - a. Refrigerant: R-410A
    - b. Refrigerant Line Connections: Suction (vapor) and liquid lines extend outside cabinet with sweat connections
    - c. Copper Tube/Enhanced Fin Evaporator Coil:
      1. Twin coils in “A” configuration
      2. Lanced, ripple-edged aluminum fins
      3. Seamless copper tubing
      4. Rifled copper tubing
      5. Flared shoulder tubing joints and silver soldering
      6. Factory leak tested under high pressure
    - d. Check and Expansion Valve:

1. Factory installed internal to cabinet
2. Chatleff style fitting, wide range valve
3. Direct Drive Blower:
  - a. Statically and dynamically balanced before installation
  - b. Resiliently mounted multi-speed leadless motor with plug-in connections
  - c. Selectable speeds
  - d. Easily removed for servicing
  - e. Time delay blower relay
4. Transformer and Blower Cooling Relay:
  - a. 24 V transformer and blower cooling relay
  - b. Factory installed in unit control box
5. Filter:
  - a. Disposable 1-inch filter furnished
  - b. Rails furnished in cabinet
  - c. 1-inch (25.4 mm) thick
6. [Optional Accessories]:
  - a. [Thermostat]
  - b. [Downflow Conversion Kit]
  - c. [Horizontal Support Frame Kit]
    1. [Two painted heavy gauge steel support channels]
    2. [Nuts and Bolts furnished for field assembly]
  - d. [Side Return Unit Stand (Upflow Only): Two adjustable, all aluminum frames]
  - e. [Wall Hanging bracket Kit (Upflow Only)]
    1. [Two heavy gauge steel support brackets (one for blower coil unit, one for wall mount)]
    2. [Screws for fastening bracket to unit and bolts for fastening bracket to wall]
  - f. [Electric Heat]
    1. [Circuit Breaker Model]
    2. [Field installed internal to unit cabinet]
    3. [Helix wound nichrome heating elements]
    4. [Limit control with fixed temperature off setting and automatic reset]
    5. [Supplemental thermal cutoff limit control]
    6. [Thermal sequencer relay]
    7. [Heating control relay(s)]
    8. [Heavy gauge galvanized steel control box and access cover]
    9. [Factory assembled with controls installed and wired]
    10. [Electric heat low voltage controls plug-in to blower coil unit]
  - g. [Circuit Breaker Models: Factory wired and mounted on electric heat unit]
    1. [Circuit Breaker Cover Kit]

Specifier Note: The following accessory can be used with optional electric heat when single power supply is connected to multi-circuit electric heat on all CBX series models.

- h. [Single-Point Power Source Control Box]
  1. [Heavy gauge steel, baked enamel finish]

2. [Pre-punched mounting holes, electrical inlet knockout, and terminal strip]
3. [Removable cover]
4. [Field installed, on [Top] [Side] of cabinet exterior]

Specifier Note: Edit Article below to suit project requirements. If substitutions are permitted, edit text below. Add text to refer to Division 1 Project Requirements (Product Substitutions Procedures) Section.

## **2.2 PRODUCT SUBSTITUTIONS**

- A. Substitutions: No substitutions permitted

## **PART 3 - EXECUTION**

### **3.1 MANUFACTURER'S INSTRUCTIONS**

Specifier Note: Revise article below to suit project requirements and specifier's practice.

- A. Compliance: Comply with manufacturer's written data, including product technical bulletins, product catalog installation instructions and product carton installation instructions.

### **3.2 EXAMINATION**

- A. Site Verification of Conditions: Verify substrate conditions, which have been previously installed under other sections, are acceptable for product installation in accordance with manufacturer's instructions.

### **3.3 INSTALLATION**

- A. Install CB series Blower Coil Units in accordance with manufacturer's instructions and regulations of authorities having jurisdiction.

**END OF SECTION**