

SERVICE AND APPLICATION NOTES

June 4, 2012

AHRI Rerating of Affected Model Combinations

AFFECTED MODEL

13HPX-60-230-13

ISSUE

On March 28, 2012, Lennox model 13HPX-060-230-13 was rerated in the AHRI Directory due to the results of a single system audit test by AHRI. The system combination selected for test was a 13HPX-060-230-13 matched with a Lennox air handler model CBX26UH-060-230-2. The results of the test could not support all of the performance metrics for this unit's rating. Lennox was unable to provide a second test sample to AHRI to verify the system performance because production of the 13HPX-060-230-13 was discontinued from production on April 21, 2011. All ratings associated with these models were removed from the AHRI directory on April 21, 2012 per the rules of the certification program which apply to discontinued product. This outdoor unit was replaced by the updated 13HPX-060-230-14 and 13HPX-060-230-17 units which are unaffected by this rerate.

As a result of this test, all AHRI listings that included the 13HPX-060-230-13 were reduced in capacity by 6.4% and in EER by 6.3%. The SEER and heating performance met published ratings. Consequently, the estimated national average annual operating cooling costs for these systems will be reduced by 6.4% and the estimated national average annual operating heating costs will remain unchanged.

Lennox has no inventory of these products at this time and, as such, has none of these products available for sale. Any Lennox dealers with inventory of the above unit should note the changes.

Lennox prides itself on its heritage of integrity, performance, quality, and reliability for over 100 years and makes every effort to ensure that our performance data is accurate. Variability in components and uncertainty in test measurements are why Lennox always tests multiple units to develop performance data and ratings.

