



NOTE:  
 ANY WIRES REPLACED MUST BE  
 REPLACED WITH 75°C MIN. RATED  
 WIRE EXCEPT THE PILOT SENSOR WIRE  
 WHICH MUST BE U.L. TYPE 3212.

CIRCUITS ENERGIZED  
 OPERATING CONDITION  
 HEATING R-W  
 COOLING R-G-Y  
 FAN CONTROL R-G  
 "ON" POSITION

WIRING SCHEMATIC  
 S8600C IGNITION CONTROL

