



NOTE-
FOR USE WITH COPPER CONDUCTORS
ONLY. REFER TO UNIT RATING
PLATE FOR MINIMUM CIRCUIT
AMPACITY AND MAXIMUM OVER-
CURRENT PROTECTION SIZE

KEY	DESCRIPTION	COMPONENT
B1	COMPRESSOR	
B4	MOTOR-OUTDOOR FAN	
C1	CAPACITOR-OUTDOOR FAN	
CMC1	CONTROL-DEFROST	
HRI	HEATER-COMPRESSOR	
K1,-1	CONTACTOR-COMPRESSOR	
L1	VALVE-REVERSING	
S4	SWITCH-HIGH PRESSURE	
S6	SWITCH-DEFROST	

— LINE VOLTAGE FIELD INSTALLED
- - CLASS II VOLTAGE FIELD INSTALLED

LENNOX Industries Inc. WIRING DIAGRAM 10/97

HEAT PUMP-OUTDOOR UNITS

10HPB36-1Y, 2Y-OPT 10HPB48-1Y, 2Y-OPT
10HPB42-1Y, 2Y-OPT 10HPB60-1Y, 2Y-OPT

HEAT PUMP SECTION-B

Supersedes Form No. New Form No.
532, 655W

WARNING-
ELECTRIC SHOCK HAZARD, CAN CAUSE INJURY OR
DEATH. UNIT MUST BE GROUND IN ACCORDANCE
WITH NATIONAL AND LOCAL CODES.