



- △ WIRE USED ON UNITS WITH S.A. SMOKE DETECTORS ONLY
- △ WIRE USED ON UNITS WITH R.A. SMOKE DETECTOR ONLY AND NOT USED ON UNITS WHERE BOTH R.A. AND S.A. SMOKE DETECTORS ARE EMPLOYED
- △ WIRE USED ON UNITS WHERE BOTH R.A. AND S.A. SMOKE DETECTORS ARE EMPLOYED
- △ WIRE USED ON UNITS WITH R.A. SMOKE DETECTOR ONLY AND BOTH R.A. AND S.A.

DISCONNECT ALL POWER BEFORE SERVICING
 WARNING-ELECTRIC SHOCK HAZARD,CAN CAUSE INJURY OR DEATH. UNIT MUST BE GROUNDED IN ACCORDANCE WITH NATIONAL AND LOCAL CODES
 IF ANY WIRE IN THIS APPLIANCE IS REPLACED, IT MUST BE REPLACED WITH WIRE OF LIKE SIZE, RATING, INSULATION THICKNESS AND TERMINATION

NOTE-FOR USE WITH COPPER CONDUCTORS ONLY. REFER TO UNIT RATING PLATE FOR MINIMUM CIRCUIT AMPACITY AND MAXIMUM OVERCURRENT PROTECTION SIZE
 ——— DESIGNATES OPTIONAL WIRING
 ——— CLASS II FIELD INSTALLED
 ——— LINE VOLTAGE FIELD INSTALLED NEC/CEC CLASS I
 NOTE:ALL REMAINING WIRES FACTORY INSTALLED

FOR SCHEMATIC AND KEY CHART SEE 534,905W

LENNOX Industries Inc. WIRING DIAGRAM 11/04

COOLING UNITS-PACKAGED

LCE120HN 1Y-B-60KW
 DANFOSS MODULE AND
 MANUAL FRESH AIR

COOLING SECTION

Supersedes Form No. New Form No.
 534,906W

© 2004 Litho U.S.A.