




| DESCRIPTION |                                     |
|-------------|-------------------------------------|
| KEY         | COMPONENT                           |
| CB1         | CIRCUIT BREAKER-ELECT HEAT          |
| HE1         | ELEMENT-ELECTRIC HEAT 1             |
| K32,-1      | RELAY-ELECTRIC HEAT                 |
| S15         | SWITCH-LIMIT, PRIMARY, ELECT HEAT   |
| S20         | SWITCH-LIMIT, SECONDARY, ELECT HEAT |
| TB2         | TERMINAL STRIP-UNIT                 |

NOTE: USE COPPER CONDUCTORS ONLY

- REFER TO UNIT NAMEPLATE FOR MINIMUM CIRCUIT AMPACITY AND MAXIMUM OVERCURRENT PROTECTION SIZE.
- CONNECT POWER WIRES FROM UNT LABELED L1 AND L2, TO TB2 TERMINAL STRIP ON HEATER PLATE.
- CONNECT WIRES 1 THRU 9 TO P8 (9 PIN CONNECTOR) ON AHC CONTROL









| DESCRIPTION                         |  |
|-------------------------------------|--|
| COMPONENT                           |  |
| CIRCUIT BREAKER-ELECT HEAT          |  |
| ELEMENT-ELECTRIC HEAT 1             |  |
| RELAY-ELECTRIC HEAT                 |  |
| SWITCH-LIMIT, PRIMARY, ELECT HEAT   |  |
| SWITCH-LIMIT, SECONDARY, ELECT HEAT |  |
| TERMINAL STRIP-UNIT                 |  |
|                                     |  |

NOTE: USE COPPER CONDUCTORS ONLY

- REFER TO UNIT NAMEPLATE FOR MINIMUM CIRCUIT AMPACITY AND MAXIMUM OVERCURRENT PROTECTION SIZE.
- CONNECT POWER WIRES FROM UNT LABELED L1 AND L2, TO TB2 TERMINAL STRIP ON HEATER PLATE.
- CONNECT WIRES 1 THRU 9 TO P8 (9 PIN CONNECTOR) ON AHC CONTROL





) 2008 Litho U.S.A.