

090, 120, 150	072	KW	HE1	HE2	HE3	HE4
		25	6.25	6.25	6.25	6.25
		35	8.3	8.3	8.3	8.3


IF ANY WIRE IN THIS APPLIANCE IS REPLACED, IT MUST BE REPLACED WITH WIRE OF LIKE SIZE, RATING, INSULATION THICKNESS AND TERMINATION

WARNING-ELECTRIC SHOCK HAZARD, CAN CAUSE INJURY OR DEATH. UNIT MUST BE GROUNDED IN ACCORDANCE WITH NATIONAL AND LOCAL CODES

DISCONNECT ALL POWER BEFORE SERVICING

— LINE VOLTAGE FIELD INSTALLED  
 ◀ DENOTES OPTIONAL COMPONENTS

- ⚠ S149 SWITCH AND K220 RELAY MAY BE FIELD SUPPLIED OR US AVAILABLE KIT
- ⚠ S50 USED ON TWO STAGE UNITS
- ⚠ USE COPPER CONDUCTORS ONLY

01/12		WIRING DIAGRAM	01/12
		537525-01	
HEATING - ELECTRIC			
T3EH - TAA 072 - 150 UNITS - Y 25, 35 KW			
SECTION B3			REV 0
Supersedes 537169-01		New Form No. 537525-01	