



IF ANY WIRE IN THIS APPLIANCE IS REPLACED, IT MUST BE REPLACED WITH WIRE OF LIKE SIZE, RATING, INSULATION THICKNESS AND TERMINATION

WARNING-ELECTRIC SHOCK HAZARD, CAN CAUSE INJURY OR DEATH. UNIT MUST BE GROUNDED IN ACCORDANCE WITH NATIONAL AND LOCAL CODES

DISCONNECT ALL POWER BEFORE SERVICING

— LINE VOLTAGE FIELD INSTALLED
 ◀ DENOTES OPTIONAL COMPONENTS

- ⚠ S149 SWITCH AND K220 RELAY MAY BE FIELD SUPPLIED OR USE AVAILABLE KIT
- ⚠ S50 USED ON TWO STAGE UNITS
- ⚠ USE COPPER CONDUCTORS ONLY

01/12		WIRING DIAGRAM	01/12
		537527-01	
HEATING - ELECTRIC			
T3EH - TAA 180, 240 UNITS - Y 30,40 KW			
SECTION B3			REV 0
Supersedes 537208-01		New Form No. 537527-01	