



| KEY | COMPONENT |
|---------|--------------------------------|
| B3 | MOTOR-BLOWER |
| J7 | JACK-ELECT HT SUB-BASE KIT |
| K3,-1 | RELAY-BLOWER |
| K43,-1 | RELAY-ECONOMIZER BLOWER |
| K220,-1 | RELAY-OVERFLOW |
| P7 | PLUG - ELECT HT SUB BASE KIT |
| S42 | RELAY-OVERLOAD,BLOWER MTR |
| S49 | SWITCH-FREEZESTAT COMPRESSOR 1 |
| S50 | SWITCH-FREEZESTAT COMPRESSOR 2 |
| S149 | SWITCH-OVERFLOW |
| TB1 | TERMINAL STRIP-CLASS II VOLT |

IF ANY WIRE IN THIS APPLIANCE IS REPLACED, IT MUST BE REPLACED WITH WIRE OF LIKE SIZE, RATING, INSULATION THICKNESS AND TERMINATION

WARNING-ELECTRIC SHOCK HAZARD, CAN CAUSE INJURY OR DEATH. UNIT MUST BE GROUNDED IN ACCORDANCE WITH NATIONAL AND LOCAL CODES

DISCONNECT ALL POWER BEFORE SERVICING

← DENOTES OPTIONAL COMPONENTS

- △ S149 SWITCH AND K220 RELAY MAY BE FIELD SUPPLIED OR USE AVAILABLE KIT
- △ S50 USED ON TWO STAGE UNITS
- △ "M" VOLTAGE UNITS ONLY
- △ FOR USE WITH COPPER CONDUCTORS ONLY

| | | | |
|-------------------------|--|----------------|-------|
| 01/12 | | WIRING DIAGRAM | 01/12 |
| | | 537530-01 | |
| BLOWER | | | |
| TAA 072 - 240 - G,J,M,Y | | | |
| SECTION B1 | | | REV 0 |
| Supersedes | | New Form No. | |
| | | 537530-01 | |