


P VOLT

048,060	KW	HE1	HE2	HE3
930	5	5	5	5
10	7.5	7.5	7.5	7.5
15	10	10	10	10
22.5	15	15	15	15

G,J,M,Y

048,060	KW	HE1	HE2
96	5	5	5
10	7.5	7.5	7.5
15	10	10	10
22.5	15	15	15

Motorized OAD



- ▲ NOTE - FOR USE WITH COPPER CONDUCTORS ONLY REFER TO UNIT RATING PLATE FOR MINIMUM CIRCUIT AMPACITY AND MAXIMUM OVERCURRENT PROTECTION SIZE.
- ▲ IMPORTANT: TO PREVENT MOTOR BURNOUT, NEVER CONNECT MORE THAN ONE MOTOR LEAD TO ANY ONE CONNECTION. TAPE UNUSED MOTOR LEADS
- ▲ P-Y VOLT T1 WITH 208V TAP
- ▲ ELECTRIC HEAT FIELD OPTION
- ▲ LOW AMBIENT KIT
- ▲ THERMOSTAT/SENSOR SUPPLIED BY USER
- ▲ REMOVE P3 WHEN ECONOMIZER OR OADM IS USED
- ▲ TIME CLOCK CONTACTS (097) CLOSED OCCUPIED
- ▲ A7 ENTHALPHY SENSOR MAY BE USED INSTEAD OF S175 TEMPERATURE SWITCH AND RESISTOR
- ▲ REMOVE P2 WHEN ELECTRIC HEAT IS USED

--- DESIGNATES OPTIONAL WIRING
 - - - CLASS II FIELD WIRING

10/14

WIRING DIAGRAM

537646-02

UNIT DIAGRAM

10/14

ZC - 036, 048, 060

SECTION ALL

Supersedes

New Form No.

537646-02

REV 0