



P VOLT

	KW	HE1	HE2	HE3
048,060	5	5	5	5
96	7.5	7.5	7.5	7.5
10	10			
22.5	15			
	22.5	7.5	7.5	7.5

G,J,M,Y

	KW	HE1	HE2
048,060	5	7.5	7.5
96	7.5	7.5	7.5
10	10		
22.5	15		
	22.5	7.5	7.5

10/14

WIRING DIAGRAM 10/14

UNIT DIAGRAM 537709-02

ZC - 036, 048, 060

SECTION ALL

Supersedes New Form No. 537709-02

REV 0

- ▲ NOTE - FOR USE WITH COPPER CONDUCTORS ONLY REFER TO UNIT RATING PLATE FOR MINIMUM CIRCUIT AMPACITY AND MAXIMUM OVERCURRENT PROTECTION SIZE.
- ▲ IMPORTANT: TO PREVENT MOTOR BURNOUT, NEVER CONNECT MORE THAN ONE MOTOR LEAD TO ANY ONE CONNECTION. TAPE UNUSED MOTOR LEADS
- ▲ P, Y VOLT T1 WITH 208V TAP
- ▲ ELECTRIC HEAT FIELD OPTION
- ▲ LOW AMBIENT KIT
- ▲ THERMOSTAT/SENSOR SUPPLIED BY USER
- ▲ TIME CLOCK CONTACTS (OPT) CLOSED OCCUPIED
- ▲ OUTDOOR AIR TEMPERATURE SENSOR, RT26, OR MAKE CONNECTION AS SHOWN.
- ▲ REMOVE P2 WHEN ELECTRIC HEAT IS USED
- ▲ PROGRAMMABLE, USE FOR EXHAUST FAN 2 OUTPUT OR ERV OR SYSTEM ALARM OUTPUT.

DESIGNATES OPTIONAL WIRING  
CLASS II FIELD WIRING