



- ▲ NOTE - FOR USE WITH COPPER CONDUCTORS ONLY REFER TO UNIT RATING PLATE FOR MINIMUM CIRCUIT AMPACITY AND MAXIMUM OVERCURRENT PROTECTION SIZE.
- ▲ IMPORTANT: TO PREVENT MOTOR BURNOUT, NEVER CONNECT MORE THAN ONE MOTOR LEAD TO ANY ONE CONNECTION. TAPE UNUSED MOTOR LEADS
- ▲ P.Y VOLT T1 WITH 208V TAP
- ▲ T3 USED ON 480V AND 600V UNITS
- ▲ LOW AMBIENT KIT
- ▲ THERMOSTAT/SENSOR SUPPLIED BY USER
- ▲ TIME CLOCK CONTACTS (OPT) CLOSED OCCUPIED
- ▲ OUTDOOR AIR TEMPERATURE SENSOR RT26 OR OUTDOOR AIR ENTHALPY SENSOR A7 MAY BE USED. MAKE CONNECTION AS SHOWN.
- ▲ K72 AND GV1 2 STG ARE USED ON TWO STAGE UNITS.
- ▲ ZGA 036,048,060 ONLY.
- ▲ ZSB MODELS ONLY.
- ▲ ZGA 072 074 DL48 NOT USED.
- ▲ SEE SECTION E DIAGRAMS FOR 2 SPEED BELT DRIVE SYSTEMS.

10/15

537710-02

WIRING DIAGRAM

10/15

UNIT DIAGRAM

ZGA 036,048,060,072,074

ZGB 036,048,060,074

SECTION ALL

REV. 1

New Form No. 537710-02

Supersedes 537710-01

DESIGNATES OPTIONAL WIRING

CLASS II FIELD WIRING

INDICATES MICRO PROCESSOR