



P VOLT	KW	HE1	HE2	HE3
048,060	5	5	5	5
96	7.5	7.5	7.5	7.5
10	15	15	15	15
22.5	7.5	7.5	7.5	7.5

G, J, M, Y	KW	HE1	HE2
048,060	5	5	5
036	10	10	10
15	15	15	15
22.5	15	15	7.5

DESIGNATES OPTIONAL WIRING
CLASS II FIELD WIRING

10/15

537711-03

WIRING DIAGRAM

10/15

UNIT DIAGRAM

ZH - 036, 048, 060

SECTION ALL

REV. 2

Supersedes 537711-02

New Form No. 537711-03

- ▲ NOTE - FOR USE WITH COPPER CONDUCTORS ONLY. REFER TO UNIT RATING PLATE FOR MINIMUM CIRCUIT AMPACITY AND MAXIMUM OVERCURRENT PROTECTION SIZE.
- ▲ IMPORTANT: TO PREVENT MOTOR BURNOUT, NEVER CONNECT MORE THAN ONE MOTOR LEAD TO ANY ONE CONNECTION. TAPE UNUSED MOTOR LEADS
- ▲ P-Y VOLT T1 WITH 208V TAP
- ▲ ELECTRIC HEAT FIELD OPTION
- ▲ LOW AMBIENT KIT
- ▲ K1-A TO K1-FAN JUMPER ON G.J.M UNITS ONLY
- ▲ THERMOSTAT/SENSOR SUPPLIED BY USER
- ▲ TIME CLOCK CONTACTS (OPT) CLOSED OCCUPIED
- ▲ A OUTDOOR AIR TEMPERATURE SENSOR RT26 OR USED. MAKE CONNECTION AS SHOWN.
- ▲ PROGRAMMABLE USE FOR EXHAUST FAN 2 OUTPUT OR ENV OR SYSTEM ALARM OUTPUT.
- ▲ ZH4 MODELS ONLY
- ▲ ZHB MODELS ONLY
- ▲ SEE SECTION E DIAGRAMS FOR 2 SPEED BELT DRIVE SYSTEMS