



- ⚠ K3 CONTACTOR IS DISABLED AND IS BEING USED AS A TERMINAL BLOCK
- ⚠ ENERGIZING K3 COIL WILL BLOW THE INVERTER
- ⚠ HEAT PUMP UNITS CONNECT WIRE LABEL HEAT (W1) TO TB1-W1 LOCATION
- ⚠ K1-LINE AND K2-LINE CAN BE USED TO SUBSTITUTE K3-LINE

← DENOTES OPTIONAL COMPONENTS
 — LINE VOLTAGE FIELD INSTALLED

09/14		WIRING DIAGRAM	09/14
		537745-01	
COOLING			
MSAV BLOWER - NO BYPASS, GENERIC			
SECTION B			REV. 0
Supersedes	New Form No. 537745-01		