

**LGH/LCH 156H/180H/210H (3-Compressor) MSAV**

Parameter	Factory Setting			Field Setting	Description
	156	180	210		
<b>Note: Any changes to Smoke CFM setting must be adjusted before the other CFM settings. Use SETTINGS &gt; RTU OPTIONS &gt; EDIT PARAMETERS</b>					
12	5200 CFM	6000 CFM	7000 CFM	CFM	Blower CFM during smoke detection.
<b>SETUP &gt; TEST &amp; BALANCE (can also use SETTINGS &gt; RTU OPTIONS &gt; BLOWER &gt; SPEEDS)</b>					
	5200 CFM	6000 CFM	7000 CFM	CFM	Blower CFM during heating.
	4675 CFM	5400 CFM	6300 CFM	CFM	Blower CFM during compressor 3 operation.
	3375 CFM	3900 CFM	4550 CFM	CFM	Blower CFM during compressor 2 operation.
	3375 CFM	3900 CFM	4550 CFM	CFM	Blower CFM during compressor 1 operation.
	5200 CFM	6000 CFM	7000 CFM	CFM	Blower CFM during ventilation.
<b>SETUP &gt; TEST &amp; BALANCE (can also use SETTINGS &gt; RTU OPTIONS &gt; DAMPER)</b>					
	0%	0%	0%	%	Damper min. position during LOW blower operation.
	0%	0%	0%	%	Damper min. position during HIGH blower operation.
	50%	50%	50%	%	Min. damper % for stage 1 power exhaust operation.
<b>SETTINGS &gt; RTU OPTIONS &gt; EDIT PARAMETERS</b>					
29	101%	101%	101%	%Open	Damper minimum position during G blower operation. (Setting parameter 29 to "101" disables parameter 29 and passes control to parameter 9 or 132)
219	70%	70%	70%	%	Min. damper % for stage 2 power exhaust operation.
216	10%	10%	10%	%	Deadband % for stage 1 power exhaust operation.
220	10%	10%	10%	%	Deadband % for stage 2 power exhaust operation.
224	100	100	100	Sec	Stage 1 power exhaust off-delay in seconds.
30	70%	70%	70%	%Speed	Minimum blower speed % for stage 2 power exhaust operation.



**LGH/LCH 156H/180H/210H (3-Compressor) MSAV**

Parameter	Factory Setting			Field Setting	Description
	156	180	210		
<b>Note: Any changes to Smoke CFM setting must be adjusted before the other CFM settings. Use SETTINGS &gt; RTU OPTIONS &gt; EDIT PARAMETERS</b>					
12	5200 CFM	6000 CFM	7000 CFM	CFM	Blower CFM during smoke detection.
<b>SETUP &gt; TEST &amp; BALANCE (can also use SETTINGS &gt; RTU OPTIONS &gt; BLOWER &gt; SPEEDS)</b>					
	5200 CFM	6000 CFM	7000 CFM	CFM	Blower CFM during heating.
	4675 CFM	5400 CFM	6300 CFM	CFM	Blower CFM during compressor 3 operation.
	3375 CFM	3900 CFM	4550 CFM	CFM	Blower CFM during compressor 2 operation.
	3375 CFM	3900 CFM	4550 CFM	CFM	Blower CFM during compressor 1 operation.
	5200 CFM	6000 CFM	7000 CFM	CFM	Blower CFM during ventilation.
<b>SETUP &gt; TEST &amp; BALANCE (can also use SETTINGS &gt; RTU OPTIONS &gt; DAMPER)</b>					
	0%	0%	0%	%	Damper min. position during LOW blower operation.
	0%	0%	0%	%	Damper min. position during HIGH blower operation.
	50%	50%	50%	%	Min. damper % for stage 1 power exhaust operation.
<b>SETTINGS &gt; RTU OPTIONS &gt; EDIT PARAMETERS</b>					
29	101%	101%	101%	%Open	Damper minimum position during G blower operation. (Setting parameter 29 to "101" disables parameter 29 and passes control to parameter 9 or 132)
219	70%	70%	70%	%	Min. damper % for stage 2 power exhaust operation.
216	10%	10%	10%	%	Deadband % for stage 1 power exhaust operation.
220	10%	10%	10%	%	Deadband % for stage 2 power exhaust operation.
224	100	100	100	Sec	Stage 1 power exhaust off-delay in seconds.
30	70%	70%	70%	%Speed	Minimum blower speed % for stage 2 power exhaust operation.

