

LGH/LCH 240H/300S (4-Compressor) MSAV

Parameter	Factory Setting		Field Setting	Description
	240S	300S		
Note: Any changes to Smoke CFM setting must be adjusted before the other CFM settings. Use SETTINGS > RTU OPTIONS > EDIT PARAMETERS				
12	8000 CFM	10000 CFM	CFM	Blower CFM during smoke detection.
SETUP > TEST & BALANCE (can also use SETTINGS > RTU OPTIONS > BLOWER > SPEEDS)				
	8000 CFM	10000 CFM	CFM	Blower CFM during heating.
	7200 CFM	9000 CFM	CFM	Blower CFM during compressor 4 operation.
	5200 CFM	6500 CFM	CFM	Blower CFM during compressor 3 operation. This parameter is inactive for thermostats with 2-stage cooling.
	5200 CFM	6500 CFM	CFM	Blower CFM during compressor 2 operation.
	5200 CFM	6500 CFM	CFM	Blower CFM during compressor 1 operation. This parameter is inactive for thermostats with 2-stage or 3-stage cooling.
	8000 CFM	10000 CFM	CFM	Blower CFM during ventilation.
SETUP > TEST & BALANCE (can also use SETTINGS > RTU OPTIONS > DAMPER)				
	0%	0%	%	Damper min. position during LOW blower operation.
	0%	0%	%	Damper min. position during HIGH blower operation.
	50%	50%	%	Min. damper % for stage 1 power exhaust operation.
SETTINGS > RTU OPTIONS > EDIT PARAMETERS				
29	101%	101%	%Open	Damper minimum position during G blower operation. (Setting parameter 29 to "101" disables parameter 29 and passes control to parameter 9 or 132)
219	70%	70%	%	Min. damper % for stage 2 power exhaust operation.
216	10%	10%	%	Deadband % for stage 1 power exhaust operation.
220	10%	10%	%	Deadband % for stage 2 power exhaust operation.
224	100	100	Sec	Stage 1 power exhaust off-delay in seconds.
30	70%	70%	%Speed	Minimum blower speed % for stage 2 power exhaust operation.



LGH/LCH 240H/300S (4-Compressor) MSAV

Parameter	Factory Setting		Field Setting	Description
	240S	300S		
Note: Any changes to Smoke CFM setting must be adjusted before the other CFM settings. Use SETTINGS > RTU OPTIONS > EDIT PARAMETERS				
12	8000 CFM	10000 CFM	CFM	Blower CFM during smoke detection.
SETUP > TEST & BALANCE (can also use SETTINGS > RTU OPTIONS > BLOWER > SPEEDS)				
	8000 CFM	10000 CFM	CFM	Blower CFM during heating.
	7200 CFM	9000 CFM	CFM	Blower CFM during compressor 4 operation.
	5200 CFM	6500 CFM	CFM	Blower CFM during compressor 3 operation. This parameter is inactive for thermostats with 2-stage cooling.
	5200 CFM	6500 CFM	CFM	Blower CFM during compressor 2 operation.
	5200 CFM	6500 CFM	CFM	Blower CFM during compressor 1 operation. This parameter is inactive for thermostats with 2-stage or 3-stage cooling.
	8000 CFM	10000 CFM	CFM	Blower CFM during ventilation.
SETUP > TEST & BALANCE (can also use SETTINGS > RTU OPTIONS > DAMPER)				
	0%	0%	%	Damper min. position during LOW blower operation.
	0%	0%	%	Damper min. position during HIGH blower operation.
	50%	50%	%	Min. damper % for stage 1 power exhaust operation.
SETTINGS > RTU OPTIONS > EDIT PARAMETERS				
29	101%	101%	%Open	Damper minimum position during G blower operation. (Setting parameter 29 to "101" disables parameter 29 and passes control to parameter 9 or 132)
219	70%	70%	%	Min. damper % for stage 2 power exhaust operation.
216	10%	10%	%	Deadband % for stage 1 power exhaust operation.
220	10%	10%	%	Deadband % for stage 2 power exhaust operation.
224	100	100	Sec	Stage 1 power exhaust off-delay in seconds.
30	70%	70%	%Speed	Minimum blower speed % for stage 2 power exhaust operation.

