

# SERVICE AND APPLICATION NOTES

December 11, 2013  
Re-issued May 28, 2015  
H-12-12

## **PolyPro® By DuraVent Approval & Installation Requirements**

Lennox Industries is pleased to announce that PolyPro by DuraVent vent pipe, fittings and terminations have been approved for use on all models of Lennox and Aire-Flo condensing gas furnaces. Both 2" and 3" vent pipe diameters have been approved as an alternative to PVC and ABS materials, when installed per PolyPro by DuraVent installation instructions. Polypro Flex by DuraVent is also approved by Lennox in 2" and 3" diameter when used as a chimney liner up to 50'.

Follow the enclosed manufacturers instructions using Polypro Flex as a chimney liner. When using the PolyPro by DuraVent venting system, the vent pipe requirements stated in the unit installation instruction – minimum & maximum vent lengths, termination clearances, etc. – apply and must be followed. Follow instructions provided with PolyPro by DuraVent venting system where applicable or if requirements are more restrictive. The PolyPro by DuraVent venting system must also follow the un-insulated and unconditioned space criteria listed in the furnace installation instruction.

Lennox has approved the use of DuraVent manufactured vent terminations. When applying these terminations, use 12 feet as the equivalent vent length in addition to the equivalent length of the pipe and fittings.

