

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

AIR HANDLERS

Entering Wet Bulb Temperature	Total Air Volume		Outdoor Air Temperature Entering Outdoor Coil																							
			85°F (29°C)						95°F (35°C)						105°F (41°C)						115°F (46°C)					
			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb		
			kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C
COOLING CAPACITY - AC13-018 TXV System with [CB27UH-018]																										
63°F (17°C)	525	250	18.2	5.3	1.05	.75	.88	1.00	17.4	5.1	1.16	.76	.90	1.00	16.5	4.8	1.28	.77	.93	1.00	15.5	4.5	1.42	.80	.96	1.00
	600	285	18.8	5.5	1.05	.77	.92	1.00	17.9	5.2	1.16	.79	.95	1.00	17.0	5.0	1.28	.81	.97	1.00	16.1	4.7	1.43	.83	1.00	1.00
	675	320	19.3	5.7	1.06	.80	.96	1.00	18.5	5.4	1.16	.82	.98	1.00	17.6	5.2	1.29	.84	1.00	1.00	16.8	4.9	1.43	.87	1.00	1.00
67°F (19°C)	525	250	19.4	5.7	1.06	.59	.72	.84	18.6	5.5	1.16	.59	.73	.86	17.7	5.2	1.29	.60	.75	.88	16.7	4.9	1.43	.61	.77	.91
	600	285	20.0	5.9	1.06	.60	.75	.88	19.2	5.6	1.17	.61	.76	.91	18.3	5.4	1.29	.62	.78	.93	17.2	5.0	1.44	.64	.80	.96
	675	320	20.6	6.0	1.07	.63	.78	.93	19.8	5.8	1.17	.63	.79	.95	18.8	5.5	1.30	.64	.81	.97	17.7	5.2	1.44	.66	.84	1.00
71°F (22°C)	525	250	20.6	6.0	1.07	.45	.57	.69	19.8	5.8	1.17	.45	.58	.70	18.9	5.5	1.30	.45	.58	.72	17.9	5.2	1.44	.45	.60	.74
	600	285	21.4	6.3	1.07	.45	.59	.72	20.4	6.0	1.18	.45	.60	.74	19.5	5.7	1.30	.46	.61	.75	18.4	5.4	1.45	.46	.62	.77
	675	320	22.0	6.4	1.07	.47	.61	.75	21.0	6.2	1.18	.47	.62	.77	20.0	5.9	1.30	.47	.63	.78	18.9	5.5	1.45	.47	.64	.81
COOLING CAPACITY - AC13-018 TXV System with [CB27UH-024]																										
63°F (17°C)	600	285	18.8	5.5	1.05	.77	.92	1.00	18.0	5.3	1.16	.79	.95	1.00	17.0	5.0	1.28	.81	.97	1.00	16.1	4.7	1.43	.83	1.00	1.00
	675	320	19.3	5.7	1.06	.80	.96	1.00	18.4	5.4	1.16	.82	.98	1.00	17.6	5.2	1.29	.84	1.00	1.00	16.7	4.9	1.43	.87	1.00	1.00
	600	285	20.2	5.9	1.06	.60	.75	.88	19.3	5.7	1.17	.61	.76	.91	18.3	5.4	1.29	.62	.78	.93	17.3	5.1	1.44	.64	.80	.96
67°F (19°C)	675	320	20.6	6.0	1.07	.63	.78	.93	19.7	5.8	1.17	.63	.79	.95	18.8	5.5	1.30	.64	.81	.97	17.7	5.2	1.44	.66	.84	1.00
	600	285	21.4	6.3	1.07	.45	.59	.72	20.4	6.0	1.18	.45	.60	.74	19.5	5.7	1.30	.46	.61	.75	18.4	5.4	1.45	.46	.62	.77
	675	320	22.0	6.4	1.07	.47	.61	.75	21.0	6.2	1.18	.47	.62	.77	20.0	5.9	1.30	.47	.63	.78	18.9	5.5	1.45	.47	.64	.81
COOLING CAPACITY - AC13-018 TXV System with [CB30M-21/26]																										
63°F (17°C)	525	250	18.0	5.3	1.05	.74	.88	1.00	17.2	5.0	1.16	.76	.90	1.00	16.4	4.8	1.28	.77	.92	1.00	15.4	4.5	1.42	.79	.95	1.00
	600	285	18.6	5.5	1.05	.77	.92	1.00	17.8	5.2	1.16	.79	.94	1.00	16.9	5.0	1.28	.81	.97	1.00	15.9	4.7	1.42	.83	.99	1.00
	675	320	19.1	5.6	1.06	.80	.96	1.00	18.3	5.4	1.16	.82	.98	1.00	17.4	5.1	1.29	.83	1.00	1.00	16.5	4.8	1.43	.86	1.00	1.00
67°F (19°C)	525	250	19.3	5.7	1.06	.58	.71	.84	18.4	5.4	1.16	.59	.73	.86	17.5	5.1	1.29	.60	.74	.88	16.6	4.9	1.43	.61	.76	.91
	600	285	19.9	5.8	1.06	.60	.74	.88	19.0	5.6	1.17	.61	.76	.90	18.1	5.3	1.29	.62	.78	.93	17.1	5.0	1.43	.63	.80	.96
	675	320	20.4	6.0	1.06	.62	.77	.92	19.6	5.7	1.17	.63	.79	.94	18.6	5.5	1.29	.64	.81	.97	17.5	5.1	1.44	.66	.83	.99
71°F (22°C)	525	250	20.4	6.0	1.06	.44	.56	.68	19.6	5.7	1.17	.45	.57	.70	18.7	5.5	1.29	.45	.58	.71	17.7	5.2	1.44	.45	.60	.73
	600	285	21.2	6.2	1.07	.45	.59	.72	20.2	5.9	1.18	.45	.59	.73	19.3	5.7	1.30	.46	.61	.75	18.2	5.3	1.44	.46	.62	.77
	675	320	21.8	6.4	1.07	.46	.60	.74	20.8	6.1	1.18	.47	.61	.76	19.8	5.8	1.30	.47	.63	.78	18.7	5.5	1.45	.47	.64	.80
COOLING CAPACITY - AC13-018 TXV System with [CB30M-31]																										
63°F (17°C)	525	250	18.2	5.3	1.05	.75	.88	1.00	17.4	5.1	1.16	.76	.90	1.00	16.5	4.8	1.28	.77	.93	1.00	15.5	4.5	1.42	.80	.96	1.00
	600	285	18.8	5.5	1.05	.77	.92	1.00	18.0	5.3	1.16	.79	.95	1.00	17.1	5.0	1.28	.81	.97	1.00	16.1	4.7	1.43	.83	1.00	1.00
	675	320	19.3	5.7	1.06	.80	.96	1.00	18.5	5.4	1.16	.82	.98	1.00	17.6	5.2	1.29	.84	1.00	1.00	16.8	4.9	1.43	.87	1.00	1.00
67°F (19°C)	525	250	19.5	5.7	1.06	.59	.72	.84	18.6	5.5	1.16	.59	.73	.86	17.7	5.2	1.29	.60	.75	.88	16.7	4.9	1.43	.61	.77	.91
	600	285	20.2	5.9	1.06	.60	.75	.88	19.3	5.7	1.17	.61	.76	.91	18.3	5.4	1.29	.62	.78	.93	17.3	5.1	1.44	.64	.80	.96
	675	320	20.6	6.0	1.07	.63	.78	.93	19.8	5.8	1.17	.63	.79	.95	18.8	5.5	1.30	.64	.81	.97	17.7	5.2	1.44	.66	.84	1.00
71°F (22°C)	525	250	20.6	6.0	1.07	.45	.57	.69	19.8	5.8	1.17	.45	.58	.70	18.9	5.5	1.30	.45	.58	.72	17.9	5.2	1.44	.45	.60	.74
	600	285	21.4	6.3	1.07	.45	.59	.72	20.4	6.0	1.18	.45	.60	.74	19.5	5.7	1.30	.46	.61	.75	18.4	5.4	1.45	.46	.62	.77
	675	320	22.0	6.4	1.07	.47	.61	.75	21.0	6.2	1.18	.47	.62	.77	20.0	5.9	1.30	.47	.63	.78	18.9	5.5	1.45	.47	.64	.81

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

UP-FLOW INDOOR COIL WITH GAS FURNACES

Entering Wet Bulb Temperature	Total Air Volume		Outdoor Air Temperature Entering Outdoor Coil																							
			85°F (29°C)						95°F (35°C)						105°F (41°C)						115°F (46°C)					
			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb		
kBtuh	kW	75°F 24°C	80°F 27°C	85°F 29°C		kBtuh	kW	75°F 24°C	80°F 27°C	85°F 29°C		kBtuh	kW	75°F 24°C	80°F 27°C	85°F 29°C		kBtuh	kW	75°F 24°C	80°F 27°C	85°F 29°C				

COOLING CAPACITY - AC13-024 with TXV [C33-31B + G61MPV-36B-045]

63°F (17°C)	840	395	25.0	7.3	1.42	.81	.97	1.00	24.0	7.0	1.60	.82	.99	1.00	22.8	6.7	1.81	.85	1.00	1.00	21.8	6.4	2.05	.87	1.00	1.00
67°F (19°C)	840	395	26.6	7.8	1.43	.63	.78	.93	25.6	7.5	1.61	.64	.80	.96	24.2	7.1	1.83	.65	.82	.98	23.0	6.7	2.06	.67	.85	1.00
71°F (22°C)	840	395	28.2	8.3	1.44	.47	.62	.76	27.0	7.9	1.63	.47	.63	.78	25.8	7.6	1.84	.48	.64	.80	24.4	7.2	2.08	.49	.66	.82

COOLING CAPACITY - AC13-024 with RFC [C33-31B + G61MPV-36B-045]

63°F (17°C)	840	395	24.8	7.3	1.41	.81	.97	1.00	23.8	7.0	1.60	.83	.99	1.00	22.6	6.6	1.81	.85	1.00	1.00	21.6	6.3	2.05	.87	1.00	1.00
67°F (19°C)	840	395	26.4	7.7	1.42	.63	.78	.94	25.2	7.4	1.61	.64	.80	.96	24.0	7.0	1.82	.65	.82	.98	22.6	6.6	2.06	.67	.85	1.00
71°F (22°C)	840	395	28.0	8.2	1.43	.47	.61	.76	26.8	7.9	1.62	.47	.63	.78	25.6	7.5	1.83	.48	.64	.80	24.2	7.1	2.07	.48	.66	.82

COOLING CAPACITY - AC13-024 with TXV [C33-31B + G61MPV-36B-070]

63°F (17°C)	830	390	25.0	7.3	1.42	.80	.96	1.00	24.0	7.0	1.60	.82	.99	1.00	22.8	6.7	1.81	.84	1.00	1.00	21.8	6.4	2.05	.87	1.00	1.00
67°F (19°C)	830	390	26.6	7.8	1.43	.63	.78	.93	25.4	7.4	1.61	.64	.80	.95	24.2	7.1	1.83	.65	.82	.98	23.0	6.7	2.06	.66	.84	1.00
71°F (22°C)	830	390	28.2	8.3	1.44	.47	.62	.76	27.0	7.9	1.63	.47	.63	.77	25.6	7.5	1.84	.48	.64	.79	24.4	7.2	2.08	.49	.65	.82

COOLING CAPACITY - AC13-024 with RFC [C33-31B + G61MPV-36B-070]

63°F (17°C)	830	390	24.8	7.3	1.41	.80	.96	1.00	23.8	7.0	1.60	.82	.99	1.00	22.6	6.6	1.81	.84	1.00	1.00	21.6	6.3	2.05	.87	1.00	1.00
67°F (19°C)	830	390	26.4	7.7	1.42	.63	.78	.93	25.2	7.4	1.61	.64	.80	.95	24.0	7.0	1.82	.65	.82	.98	22.6	6.6	2.06	.66	.84	1.00
71°F (22°C)	830	390	28.0	8.2	1.43	.47	.61	.76	26.8	7.8	1.62	.47	.62	.77	25.4	7.4	1.83	.48	.64	.79	24.0	7.0	2.07	.48	.65	.82

COOLING CAPACITY - AC13-024 with TXV [C33-36A + G60UHV-36A-070]

63°F (17°C)	830	390	24.6	7.2	1.41	.82	.97	1.00	23.6	6.9	1.60	.83	.99	1.00	22.4	6.6	1.81	.85	1.00	1.00	21.4	6.3	2.05	.88	1.00	1.00
67°F (19°C)	830	390	25.8	7.6	1.42	.64	.79	.94	24.8	7.3	1.61	.65	.81	.96	23.6	6.9	1.82	.66	.83	.98	22.4	6.6	2.06	.68	.85	1.00
71°F (22°C)	830	390	27.0	7.9	1.43	.48	.63	.77	26.0	7.6	1.62	.49	.64	.79	24.8	7.3	1.83	.49	.65	.81	23.6	6.9	2.07	.50	.67	.83

COOLING CAPACITY - AC13-024 with RFC [C33-36A + G60UHV-36A-070]

63°F (17°C)	830	390	24.4	7.2	1.41	.81	.97	1.00	23.4	6.9	1.60	.83	.99	1.00	22.2	6.5	1.81	.85	1.00	1.00	21.2	6.2	2.04	.88	1.00	1.00
67°F (19°C)	830	390	25.6	7.5	1.42	.64	.79	.94	24.6	7.2	1.60	.65	.81	.96	23.4	6.9	1.81	.66	.83	.99	22.0	6.5	2.05	.68	.85	1.00
71°F (22°C)	830	390	26.8	7.9	1.43	.48	.63	.77	25.8	7.6	1.61	.48	.64	.79	24.6	7.2	1.82	.49	.65	.81	23.2	6.8	2.06	.49	.67	.83

COOLING CAPACITY - AC13-024 with TXV [C33-36B + G60UHV-36B-090]

63°F (17°C)	825	390	24.4	7.2	1.41	.81	.97	1.00	23.4	6.9	1.60	.83	.99	1.00	22.4	6.6	1.81	.85	1.00	1.00	21.4	6.3	2.05	.87	1.00	1.00
67°F (19°C)	825	390	25.8	7.6	1.42	.64	.79	.94	24.8	7.3	1.61	.65	.81	.96	23.6	6.9	1.82	.66	.83	.98	22.4	6.6	2.06	.67	.85	1.00
71°F (22°C)	825	390	27.0	7.9	1.43	.48	.63	.77	26.0	7.6	1.62	.48	.64	.78	24.8	7.3	1.83	.49	.65	.80	23.4	6.9	2.07	.49	.66	.83

COOLING CAPACITY - AC13-024 with RFC [C33-36B + G60UHV-36B-090]

63°F (17°C)	825	390	24.2	7.1	1.41	.81	.97	1.00	23.2	6.8	1.59	.83	.99	1.00	22.2	6.5	1.81	.85	1.00	1.00	21.2	6.2	2.04	.88	1.00	1.00
67°F (19°C)	825	390	25.6	7.5	1.42	.64	.79	.94	24.4	7.2	1.60	.65	.81	.96	23.4	6.9	1.81	.66	.83	.98	22.0	6.4	2.05	.67	.85	1.00
71°F (22°C)	825	390	26.8	7.9	1.43	.48	.62	.77	25.8	7.6	1.61	.48	.64	.78	24.6	7.2	1.82	.49	.65	.80	23.2	6.8	2.06	.49	.66	.83

COOLING CAPACITY - AC13-024 with TXV [C33-36B + G61MPV-36B-045]

63°F (17°C)	840	395	24.6	7.2	1.41	.82	.97	1.00	23.6	6.9	1.60	.83	.99	1.00	22.6	6.6	1.81	.85	1.00	1.00	21.4	6.3	2.05	.88	1.00	1.00
67°F (19°C)	840	395	25.8	7.6	1.42	.64	.79	.94	24.8	7.3	1.61	.65	.81	.96	23.6	6.9	1.82	.66	.83	.99	22.4	6.6	2.06	.68	.86	1.00
71°F (22°C)	840	395	27.2	8.0	1.43	.48	.63	.77	26.0	7.6	1.62	.48	.64	.79	24.8	7.3	1.83	.49	.65	.81	23.6	6.9	2.07	.50	.67	.83

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

UP-FLOW INDOOR COIL WITH GAS FURNACES

Table with columns for Entering Wet Bulb Temperature, Total Air Volume, and Outdoor Air Temperature Entering Outdoor Coil (85°F, 95°F, 105°F, 115°F). Sub-columns include Total Cooling Capacity, Comp Motor kW Input, and Sensible To Total Ratio (S/T) Dry Bulb.

COOLING CAPACITY - AC13-024 with TXV

[C33-38B + G61MPV-36B-070]

[C33-38B + G71MPP-36B-070]

Data table for AC13-024 with TXV showing performance metrics at various temperatures and capacities.

COOLING CAPACITY - AC13-024 with RFC

[C33-38B + G61MPV-36B-070]

[C33-38B + G71MPP-36B-070]

Data table for AC13-024 with RFC showing performance metrics at various temperatures and capacities.

DOWN-FLOW INDOOR COILS

Table with columns for Entering Wet Bulb Temperature, Total Air Volume, and Outdoor Air Temperature Entering Outdoor Coil (85°F, 95°F, 105°F, 115°F). Sub-columns include Total Cooling Capacity, Comp Motor kW Input, and Sensible To Total Ratio (S/T) Dry Bulb.

COOLING CAPACITY - AC13-024 with TXV

[CR33-24A/B-F]

Data table for AC13-024 with TXV showing performance metrics at various temperatures and capacities.

COOLING CAPACITY - AC13-024 with RFC

[CR33-30/36A/B/C-F]

Data table for AC13-024 with RFC showing performance metrics at various temperatures and capacities.

COOLING CAPACITY - AC13-024 with RFC

[CR33-30/36A/B/C-F]

Data table for AC13-024 with RFC showing performance metrics at various temperatures and capacities.

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

AIR HANDLERS

Entering Wet Bulb Temperature	Total Air Volume		Outdoor Air Temperature Entering Outdoor Coil																							
			85°F (29°C)						95°F (35°C)						105°F (41°C)						115°F (46°C)					
			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb		
			kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C

COOLING CAPACITY - AC13-024 with TXV [CBX27UH-024]

63°F (17°C)	700	330	23.8	7.0	1.41	.76	.91	1.00	22.8	6.7	1.59	.78	.93	1.00	21.6	6.3	1.80	.79	.96	1.00	20.4	6.0	2.04	.82	.98	1.00
	800	380	24.4	7.2	1.41	.80	.96	1.00	23.4	6.9	1.60	.81	.98	1.00	22.4	6.6	1.81	.83	1.00	1.00	21.2	6.2	2.05	.86	1.00	1.00
	900	425	25.0	7.3	1.42	.83	.99	1.00	24.0	7.0	1.60	.85	1.00	1.00	23.0	6.7	1.81	.87	1.00	1.00	21.8	6.4	2.05	.90	1.00	1.00
67°F (19°C)	700	330	25.2	7.4	1.42	.60	.74	.88	24.2	7.1	1.60	.61	.75	.90	23.0	6.7	1.81	.62	.77	.92	21.8	6.4	2.05	.63	.79	.95
	800	380	26.0	7.6	1.42	.62	.77	.92	24.8	7.3	1.61	.63	.79	.95	23.6	6.9	1.82	.64	.81	.97	22.4	6.6	2.06	.65	.83	.99
	900	425	26.6	7.8	1.43	.64	.80	.97	25.4	7.4	1.61	.65	.82	.98	24.2	7.1	1.82	.66	.85	1.00	22.8	6.7	2.06	.68	.87	1.00
71°F (22°C)	700	330	26.8	7.9	1.43	.45	.58	.71	25.6	7.5	1.61	.45	.59	.73	24.4	7.2	1.83	.46	.60	.74	23.2	6.8	2.06	.46	.62	.77
	800	380	27.4	8.0	1.43	.46	.60	.75	26.2	7.7	1.62	.46	.61	.76	25.0	7.3	1.83	.47	.63	.78	23.8	7.0	2.07	.47	.64	.81
	900	425	28.0	8.2	1.44	.47	.63	.78	26.8	7.9	1.62	.47	.64	.80	25.6	7.5	1.84	.48	.65	.82	24.2	7.1	2.07	.48	.67	.85

COOLING CAPACITY - AC13-024 with TXV [CBX27UH-030]

63°F (17°C)	700	330	23.8	7.0	1.41	.76	.91	1.00	22.8	6.7	1.59	.78	.93	1.00	21.8	6.4	1.80	.80	.96	1.00	20.6	6.0	2.04	.82	.99	1.00
	800	380	24.6	7.2	1.41	.80	.96	1.00	23.6	6.9	1.60	.81	.98	1.00	22.4	6.6	1.81	.83	1.00	1.00	21.2	6.2	2.05	.86	1.00	1.00
	900	425	25.2	7.4	1.42	.83	.99	1.00	24.2	7.1	1.60	.85	1.00	1.00	23.2	6.8	1.82	.87	1.00	1.00	22.0	6.4	2.05	.90	1.00	1.00
67°F (19°C)	700	330	25.4	7.4	1.42	.60	.74	.88	24.2	7.1	1.61	.61	.75	.90	23.2	6.8	1.81	.62	.77	.92	21.8	6.4	2.05	.63	.79	.95
	800	380	26.0	7.6	1.42	.62	.77	.93	25.0	7.3	1.61	.63	.79	.95	23.8	7.0	1.82	.64	.81	.97	22.4	6.6	2.06	.65	.83	1.00
	900	425	26.6	7.8	1.43	.64	.81	.97	25.4	7.4	1.61	.65	.83	.99	24.2	7.1	1.82	.66	.85	1.00	22.8	6.7	2.06	.68	.88	1.00
71°F (22°C)	700	330	26.8	7.9	1.43	.45	.58	.71	25.6	7.5	1.61	.45	.59	.73	24.4	7.2	1.83	.46	.60	.75	23.2	6.8	2.06	.46	.62	.77
	800	380	27.6	8.1	1.43	.46	.60	.75	26.4	7.7	1.62	.46	.62	.77	25.0	7.3	1.83	.47	.63	.79	23.8	7.0	2.07	.47	.64	.81
	900	425	28.2	8.3	1.44	.47	.63	.78	26.8	7.9	1.62	.47	.64	.80	25.6	7.5	1.84	.48	.65	.83	24.2	7.1	2.07	.48	.67	.85

COOLING CAPACITY - AC13-024 with TXV [CBX32MV-036]

63°F (17°C)	800	380	24.6	7.2	1.41	.80	.96	1.00	23.6	6.9	1.60	.81	.98	1.00	22.4	6.6	1.81	.83	1.00	1.00	21.2	6.2	2.05	.86	1.00	1.00
	900	425	25.2	7.4	1.42	.83	.99	1.00	24.2	7.1	1.60	.85	1.00	1.00	23.2	6.8	1.82	.87	1.00	1.00	22.0	6.4	2.05	.90	1.00	1.00
	1000	470	25.8	7.6	1.42	.86	1.00	1.00	24.8	7.3	1.61	.89	1.00	1.00	23.8	7.0	1.82	.91	1.00	1.00	22.6	6.6	2.06	.94	1.00	1.00
67°F (19°C)	800	380	26.0	7.6	1.42	.62	.77	.93	25.0	7.3	1.61	.63	.79	.95	23.8	7.0	1.82	.64	.81	.97	22.4	6.6	2.06	.65	.83	1.00
	900	425	26.6	7.8	1.43	.64	.81	.97	25.4	7.4	1.61	.65	.83	.99	24.2	7.1	1.82	.66	.85	1.00	22.8	6.7	2.06	.68	.88	1.00
	1000	470	27.0	7.9	1.43	.66	.84	1.00	25.8	7.6	1.62	.67	.86	1.00	24.6	7.2	1.83	.69	.89	1.00	23.2	6.8	2.06	.71	.92	1.00
71°F (22°C)	800	380	27.6	8.1	1.43	.46	.60	.75	26.4	7.7	1.62	.46	.62	.77	25.0	7.3	1.83	.47	.63	.79	23.8	7.0	2.07	.47	.64	.81
	900	425	28.2	8.3	1.44	.47	.63	.78	26.8	7.9	1.62	.47	.64	.80	25.6	7.5	1.84	.48	.65	.83	24.2	7.1	2.07	.48	.67	.85
	1000	470	28.6	8.4	1.44	.47	.65	.82	27.4	8.0	1.63	.48	.66	.84	26.0	7.6	1.84	.49	.68	.87	24.6	7.2	2.08	.49	.70	.89

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

UP-FLOW INDOOR COILS

Entering Wet Bulb Temperature	Total Air Volume		Outdoor Air Temperature Entering Outdoor Coil																							
			85°F (29°C)						95°F (35°C)						105°F (41°C)						115°F (46°C)					
	cfm	L/s	Total Cooling Capacity kBtuh	kW	Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity kBtuh	kW	Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity kBtuh	kW	Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity kBtuh	kW	Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb		
						75°F 24°C	80°F 27°C	85°F 29°C				75°F 24°C	80°F 27°C	85°F 29°C				75°F 24°C	80°F 27°C	85°F 29°C				75°F 24°C	80°F 27°C	85°F 29°C

COOLING CAPACITY - AC13-030 TXV System with [C33-25A/B]

63°F (17°C)	875	415	29.4	8.6	1.71	.78	.92	1.00	28.2	8.3	1.92	.80	.94	1.00	26.8	7.9	2.15	.81	.97	1.00	25.4	7.4	2.41	.83	.99	1.00
	1000	470	30.2	8.9	1.71	.81	.96	1.00	29.0	8.5	1.92	.83	.98	1.00	27.6	8.1	2.16	.85	1.00	1.00	26.4	7.7	2.43	.87	1.00	1.00
	1125	530	31.0	9.1	1.72	.84	1.00	1.00	29.6	8.7	1.93	.86	1.00	1.00	28.6	8.4	2.17	.88	1.00	1.00	27.2	8.0	2.43	.91	1.00	1.00

COOLING CAPACITY - AC13-030 TXV System with [C33-30A/B/C]

63°F (17°C)	775	365	27.8	8.1	1.69	.75	.87	.99	26.8	7.9	1.90	.76	.89	1.00	25.8	7.6	2.14	.78	.92	1.00	24.6	7.2	2.40	.80	.94	1.00
	900	425	28.6	8.4	1.70	.78	.91	1.00	27.6	8.1	1.91	.79	.93	1.00	26.6	7.8	2.15	.81	.96	1.00	25.4	7.4	2.42	.83	.99	1.00
	1025	485	29.2	8.6	1.70	.80	.94	1.00	28.2	8.3	1.92	.82	.97	1.00	27.2	8.0	2.16	.84	.99	1.00	26.2	7.7	2.43	.87	1.00	1.00

COOLING CAPACITY - AC13-030 TXV System with [C33-31A/B]

63°F (17°C)	875	415	30.2	8.9	1.71	.77	.91	1.00	29.0	8.5	1.92	.79	.94	1.00	27.6	8.1	2.16	.81	.96	1.00	26.2	7.7	2.42	.83	.99	1.00
	1000	470	31.2	9.1	1.72	.80	.95	1.00	29.8	8.7	1.93	.82	.98	1.00	28.4	8.3	2.17	.84	1.00	1.00	27.2	8.0	2.44	.86	1.00	1.00
	1125	530	31.8	9.3	1.72	.83	.99	1.00	30.6	9.0	1.94	.85	1.00	1.00	29.2	8.6	2.18	.88	1.00	1.00	28.0	8.2	2.45	.90	1.00	1.00

COOLING CAPACITY - AC13-030 TXV System with [C33-36A/B/C]

63°F (17°C)	875	415	29.4	8.6	1.71	.79	.93	1.00	28.2	8.3	1.92	.80	.95	1.00	27.0	7.9	2.15	.82	.97	1.00	25.6	7.5	2.42	.84	.99	1.00
	1000	470	30.4	8.9	1.71	.82	.97	1.00	29.0	8.5	1.93	.83	.99	1.00	27.8	8.1	2.16	.85	1.00	1.00	26.6	7.8	2.43	.88	1.00	1.00
	1125	530	31.0	9.1	1.72	.84	.99	1.00	30.0	8.8	1.93	.86	1.00	1.00	28.8	8.4	2.17	.89	1.00	1.00	27.4	8.0	2.44	.92	1.00	1.00

COOLING CAPACITY - AC13-030 TXV System with [C33-38A/B]

63°F (17°C)	875	415	30.4	8.9	1.71	.78	.92	1.00	29.2	8.6	1.93	.80	.94	1.00	27.8	8.1	2.16	.82	.97	1.00	26.4	7.7	2.43	.83	.99	1.00
	1000	470	31.4	9.2	1.72	.81	.96	1.00	30.2	8.9	1.93	.83	.99	1.00	28.8	8.4	2.17	.85	1.00	1.00	27.4	8.0	2.44	.88	1.00	1.00
	1125	530	32.2	9.4	1.73	.84	1.00	1.00	31.0	9.1	1.94	.86	1.00	1.00	29.8	8.7	2.18	.89	1.00	1.00	28.4	8.3	2.45	.91	1.00	1.00

COOLING CAPACITY - AC13-030 TXV System with [C33-42B]

63°F (17°C)	875	415	29.4	8.6	1.71	.79	.93	1.00	28.2	8.3	1.92	.80	.95	1.00	27.0	7.9	2.15	.82	.97	1.00	25.6	7.5	2.42	.84	.99	1.00
	1000	470	30.4	8.9	1.71	.82	.97	1.00	29.0	8.5	1.93	.83	.99	1.00	27.8	8.1	2.16	.85	1.00	1.00	26.6	7.8	2.43	.88	1.00	1.00
	1125	530	31.0	9.1	1.72	.84	.99	1.00	30.0	8.8	1.93	.86	1.00	1.00	28.8	8.4	2.17	.89	1.00	1.00	27.4	8.0	2.44	.92	1.00	1.00

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

DOWN-FLOW INDOOR COILS WITH GAS FURNACES

Table with columns for Entering Wet Bulb Temperature, Total Air Volume (cfm, L/s), Total Cooling Capacity (kBtuh, kW), and Sensible To Total Ratio (S/T) Dry Bulb for four outdoor air temperature ranges: 85°F (29°C), 95°F (35°C), 105°F (41°C), and 115°F (46°C). Each range includes sub-columns for 75°F, 80°F, and 85°F (24°C, 27°C, 29°C) wet bulb temperatures. The table is divided into four sections: AC13-030 TXV System with CR33-30/36B-F + G60DFV-36B-090, AC13-030 RFC System with CR33-30/36B-F + G60DFV-36B-090, AC13-030 RFC System with CR33-30/36B-F + G61MPV-36B-045, and AC13-030 RFC System with CR33-30/36B-F + G61MPV-36B-070 and CR33-30/36B-F + G71MPP-36B-070. Each section contains three rows of data for entering wet bulb temperatures of 63°F (17°C), 67°F (19°C), and 71°F (22°C).

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

HORIZONTAL INDOOR COILS

Table with columns: Entering Wet Bulb Temperature, Total Air Volume (cfm, L/s), Outdoor Air Temperature (85°F, 95°F, 105°F, 115°F), Total Cooling Capacity (kBtuh, kW), Comp Motor kW Input, Sensible To Total Ratio (S/T) Dry Bulb (75°F, 80°F, 85°F).

COOLING CAPACITY - AC13-030 TXV System with [CH33-36A/B/C-2F]

Table for AC13-030 TXV System with CH33-36A/B/C-2F, showing cooling capacity and motor input for temperatures 63°F, 67°F, and 71°F.

COOLING CAPACITY - AC13-030 TXV System with [CH33-42B-2F]

Table for AC13-030 TXV System with CH33-42B-2F, showing cooling capacity and motor input for temperatures 63°F, 67°F, and 71°F.

HORIZONTAL INDOOR COILS WITH GAS FURNACES

COOLING CAPACITY - AC13-030 TXV System with [CH33-36A-2F + G60UHV-36A-070]

Table for AC13-030 TXV System with CH33-36A-2F + G60UHV-36A-070, showing cooling capacity and motor input for temperatures 63°F, 67°F, and 71°F.

COOLING CAPACITY - AC13-030 RFC System with [CH33-36A-2F + G60UHV-36A-070]

Table for AC13-030 RFC System with CH33-36A-2F + G60UHV-36A-070, showing cooling capacity and motor input for temperatures 63°F, 67°F, and 71°F.

COOLING CAPACITY - AC13-030 TXV System with [CH33-36B-2F + G60UHV-36B-090]

Table for AC13-030 TXV System with CH33-36B-2F + G60UHV-36B-090, showing cooling capacity and motor input for temperatures 63°F, 67°F, and 71°F.

COOLING CAPACITY - AC13-030 RFC System with [CH33-36B-2F + G60UHV-36B-090]

Table for AC13-030 RFC System with CH33-36B-2F + G60UHV-36B-090, showing cooling capacity and motor input for temperatures 63°F, 67°F, and 71°F.

RATINGS

2.5 TON

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

HORIZONTAL INDOOR COILS WITH GAS FURNACES

Table with columns: Entering Wet Bulb Temperature, Total Air Volume, Outdoor Air Temperature Entering Outdoor Coil, and various capacity/ratio metrics for different indoor air temperatures (85°F, 95°F, 105°F, 115°F).

COOLING CAPACITY - AC13-030 RFC System with [CH33-42B-2F + G61MPV-36B-070]

Table showing cooling capacity and other metrics for the AC13-030 RFC system at various entering wet bulb temperatures (63°F, 67°F, 71°F).

COOLING CAPACITY - AC13-030 TXV System with [CH33-42B-2F + G61MPV-36B-071]

Table showing cooling capacity and other metrics for the AC13-030 TXV system at various entering wet bulb temperatures (63°F, 67°F, 71°F).

AIR HANDLERS

COOLING CAPACITY - AC13-030 TXV System with [CB26UH-030-R]

Table showing cooling capacity and other metrics for the AC13-030 TXV system with air handler [CB26UH-030-R] at various entering wet bulb temperatures (63°F, 67°F, 71°F).

COOLING CAPACITY - AC13-030 TXV System with [CB27UH-030]

Table showing cooling capacity and other metrics for the AC13-030 TXV system with air handler [CB27UH-030] at various entering wet bulb temperatures (63°F, 67°F, 71°F).

COOLING CAPACITY - AC13-030 TXV System with [CB27UH-036]

Table showing cooling capacity and other metrics for the AC13-030 TXV system with air handler [CB27UH-036] at various entering wet bulb temperatures (63°F, 67°F, 71°F).

COOLING CAPACITY - AC13-030 TXV System with [CB30M-21/26]

Table showing cooling capacity and other metrics for the AC13-030 TXV system with air handler [CB30M-21/26] at various entering wet bulb temperatures (63°F, 67°F, 71°F).

COOLING CAPACITY - AC13-030 TXV System with [CB30M-31]

Table showing cooling capacity and other metrics for the AC13-030 TXV system with air handler [CB30M-31] at various entering wet bulb temperatures (63°F, 67°F, 71°F).

RATINGS

2.5 TON

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

AIR HANDLERS

Entering Wet Bulb Temperature	Total Air Volume		Outdoor Air Temperature Entering Outdoor Coil																							
			85°F (29°C)						95°F (35°C)						105°F (41°C)						115°F (46°C)					
			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb		
			kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C

COOLING CAPACITY - AC13-030 TXV System with [CB30M-41]

63°F (17°C)	875	415	29.6	8.7	1.71	.77	.92	1.00	28.2	8.3	1.92	.79	.94	1.00	27.0	7.9	2.15	.80	.97	1.00	25.6	7.5	2.42	.83	.99	1.00
	1000	470	30.4	8.9	1.71	.81	.96	1.00	29.2	8.6	1.93	.82	.98	1.00	27.8	8.1	2.16	.84	1.00	1.00	26.6	7.8	2.43	.87	1.00	1.00
	1125	530	31.2	9.1	1.72	.84	.99	1.00	30.0	8.8	1.93	.86	1.00	1.00	28.6	8.4	2.17	.88	1.00	1.00	27.4	8.0	2.44	.91	1.00	1.00
67°F (19°C)	875	415	31.4	9.2	1.72	.61	.75	.89	30.2	8.9	1.93	.62	.76	.91	28.8	8.4	2.17	.63	.78	.93	27.2	8.0	2.44	.63	.80	.96
	1000	470	32.2	9.4	1.73	.63	.78	.93	30.8	9.0	1.94	.64	.80	.95	29.4	8.6	2.18	.65	.82	.97	28.0	8.2	2.44	.66	.84	1.00
	1125	530	32.8	9.6	1.73	.65	.81	.97	31.6	9.3	1.95	.66	.83	.99	30.0	8.8	2.18	.67	.86	1.00	28.4	8.3	2.45	.69	.88	1.00
71°F (22°C)	875	415	33.2	9.7	1.73	.46	.59	.73	31.8	9.3	1.95	.46	.60	.74	30.4	8.9	2.19	.47	.61	.76	28.8	8.4	2.45	.46	.62	.78
	1000	470	34.0	10.0	1.74	.46	.61	.76	32.6	9.6	1.95	.47	.62	.78	31.2	9.1	2.19	.47	.64	.79	29.6	8.7	2.46	.48	.65	.82
	1125	530	34.8	10.2	1.74	.48	.64	.80	33.4	9.8	1.96	.48	.65	.81	31.8	9.3	2.20	.49	.66	.83	30.2	8.9	2.47	.49	.68	.86

COOLING CAPACITY - AC13-030 TXV System with [CBX32MV-036] [CBX40UHV-036]

63°F (17°C)	900	425	29.8	8.7	1.71	.78	.93	1.00	28.4	8.3	1.92	.80	.95	1.00	27.2	8.0	2.16	.81	.97	1.00	25.8	7.6	2.42	.84	1.00	1.00
	1000	470	30.4	8.9	1.71	.81	.96	1.00	29.2	8.6	1.93	.82	.98	1.00	27.8	8.1	2.16	.84	1.00	1.00	26.6	7.8	2.43	.87	1.00	1.00
	1135	535	31.4	9.2	1.72	.84	.99	1.00	30.0	8.8	1.93	.86	1.00	1.00	28.8	8.4	2.17	.88	1.00	1.00	27.4	8.0	2.44	.91	1.00	1.00
67°F (19°C)	900	425	31.6	9.3	1.72	.61	.75	.90	30.4	8.9	1.94	.62	.77	.92	29.0	8.5	2.17	.63	.79	.94	27.4	8.0	2.44	.64	.81	.97
	1000	470	32.2	9.4	1.73	.63	.78	.93	30.8	9.0	1.94	.64	.80	.95	29.6	8.7	2.18	.65	.82	.97	28.0	8.2	2.44	.66	.84	1.00
	1135	535	33.0	9.7	1.73	.65	.82	.97	31.6	9.3	1.95	.66	.84	.99	30.0	8.8	2.18	.67	.86	1.00	28.6	8.4	2.45	.69	.89	1.00
71°F (22°C)	900	425	33.4	9.8	1.73	.46	.60	.73	32.0	9.4	1.95	.46	.60	.74	30.6	9.0	2.19	.47	.62	.76	29.0	8.5	2.45	.47	.63	.78
	1000	470	34.0	10.0	1.74	.46	.61	.76	32.6	9.6	1.95	.47	.62	.78	31.2	9.1	2.19	.47	.64	.79	29.8	8.7	2.46	.48	.65	.82
	1135	535	34.8	10.2	1.74	.48	.64	.79	33.4	9.8	1.96	.48	.65	.81	31.8	9.3	2.20	.48	.66	.83	30.4	8.9	2.47	.49	.68	.86

RATINGS

3 TON

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

UP-FLOW INDOOR COILS

Entering Wet Bulb Temperature	Total Air Volume		Outdoor Air Temperature Entering Outdoor Coil																	
			85°F (29°C)			95°F (35°C)			105°F (41°C)			115°F (46°C)								
	cfm	L/s	Total Cooling Capacity	Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb	Total Cooling Capacity	Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb	Total Cooling Capacity	Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb	Total Cooling Capacity	Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb						

COOLING CAPACITY - AC13-036 TXV System with

[C33-38A/B]

63°F (17°C)	1050	495	35.2	10.3	2.26	.77	.91	1.00	33.6	9.8	2.53	.79	.93	1.00	32.2	9.4	2.83	.81	.96	1.00	30.6	9.0	3.16	.83	.98	1.00
	1200	565	36.2	10.6	2.27	.80	.95	1.00	34.6	10.1	2.54	.82	.98	1.00	33.0	9.7	2.84	.84	1.00	1.00	31.6	9.3	3.17	.86	1.00	1.00
	1350	635	37.0	10.8	2.29	.83	.99	1.00	35.6	10.4	2.55	.85	1.00	1.00	34.0	10.0	2.86	.87	1.00	1.00	32.6	9.6	3.19	.90	1.00	1.00

COOLING CAPACITY - AC13-036 TXV System with

[C33-38B/C]

63°F (17°C)	1050	495	35.4	10.4	2.26	.77	.90	1.00	34.0	10.0	2.53	.78	.92	1.00	32.4	9.5	2.83	.80	.95	1.00	30.8	9.0	3.16	.82	.98	1.00
	1200	565	36.6	10.7	2.28	.80	.95	1.00	35.0	10.3	2.55	.81	.97	1.00	33.4	9.8	2.85	.83	.99	1.00	31.8	9.3	3.18	.86	1.00	1.00
	1350	635	37.4	11.0	2.29	.82	.98	1.00	35.8	10.5	2.56	.84	1.00	1.00	34.2	10.0	2.86	.87	1.00	1.00	32.8	9.6	3.20	.89	1.00	1.00

COOLING CAPACITY - AC13-036 RFC System with

[C33-43B/C]

63°F (17°C)	1000	470	35.2	10.3	2.25	.75	.88	1.00	33.8	9.9	2.52	.77	.91	1.00	32.2	9.4	2.81	.79	.93	1.00	30.8	9.0	3.14	.80	.95	1.00
	1150	545	36.4	10.7	2.26	.78	.92	1.00	34.8	10.2	2.53	.80	.95	1.00	33.2	9.7	2.83	.82	.97	1.00	31.6	9.3	3.16	.84	1.00	1.00
	1300	615	37.2	10.9	2.27	.81	.96	1.00	35.6	10.4	2.54	.82	.98	1.00	34.0	10.0	2.84	.84	1.00	1.00	32.6	9.6	3.17	.87	1.00	1.00

COOLING CAPACITY - AC13-036 TXV System with

[C33-50/60C]

63°F (17°C)	1050	495	35.2	10.3	2.26	.76	.90	1.00	33.8	9.9	2.53	.78	.92	1.00	32.2	9.4	2.83	.80	.95	1.00	30.6	9.0	3.16	.82	.97	1.00
	1200	565	36.2	10.6	2.27	.79	.94	1.00	34.8	10.2	2.54	.81	.96	1.00	33.2	9.7	2.84	.83	.99	1.00	31.6	9.3	3.17	.85	1.00	1.00
	1350	635	37.2	10.9	2.29	.82	.97	1.00	35.6	10.4	2.56	.84	1.00	1.00	34.0	10.0	2.86	.86	1.00	1.00	32.6	9.6	3.19	.89	1.00	1.00

UP-FLOW INDOOR COIL WITH GAS FURNACES

COOLING CAPACITY - AC13-036 TXV System with

[C33-38A + G60UHV-36A-070]

63°F (17°C)	1085	510	35.4	10.4	2.26	.77	.92	1.00	33.8	9.9	2.53	.79	.94	1.00	32.4	9.5	2.83	.81	.96	1.00	30.6	9.0	3.16	.83	.99	1.00
	1230	580	36.4	10.7	2.27	.80	.96	1.00	34.8	10.2	2.54	.82	.98	1.00	33.2	9.7	2.84	.85	1.00	1.00	31.8	9.3	3.18	.87	1.00	1.00
	1380	650	37.2	10.9	2.29	.84	.99	1.00	35.6	10.4	2.55	.86	1.00	1.00	34.2	10.0	2.86	.88	1.00	1.00	32.8	9.6	3.20	.91	1.00	1.00

COOLING CAPACITY - AC13-036 RFC System with

[C33-38A + G60UHV-36A-070]

63°F (17°C)	1085	510	35.4	10.4	2.25	.77	.91	1.00	34.0	10.0	2.52	.79	.93	1.00	32.4	9.5	2.82	.80	.96	1.00	31.0	9.1	3.15	.82	.98	1.00
	1230	580	36.4	10.7	2.27	.80	.95	1.00	35.0	10.3	2.53	.82	.97	1.00	33.4	9.8	2.83	.84	1.00	1.00	31.8	9.3	3.16	.86	1.00	1.00
	1380	650	37.2	10.9	2.28	.82	.98	1.00	35.6	10.4	2.54	.85	1.00	1.00	34.2	10.0	2.84	.87	1.00	1.00	32.8	9.6	3.18	.90	1.00	1.00

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

UP-FLOW INDOOR COIL WITH GAS FURNACES

Table with columns for Entering Wet Bulb Temperature, Total Air Volume (cfm, L/s), Total Cooling Capacity (kBtuh, kW), Comp Motor kW Input, and Sensible To Total Ratio (S/T) Dry Bulb for Outdoor Air Temperature Entering Outdoor Coil (85°F, 95°F, 105°F, 115°F).

COOLING CAPACITY - AC13-036 TXV System with [C33-38B + G60UHV-36B-090]

Table with columns for Entering Wet Bulb Temperature (63°F, 67°F, 71°F) and various capacity and ratio metrics for the AC13-036 TXV system with C33-38B + G60UHV-36B-090.

COOLING CAPACITY - AC13-036 RFC System with [C33-38B + G61MPV-36B-045]

Table with columns for Entering Wet Bulb Temperature (63°F, 67°F, 71°F) and various capacity and ratio metrics for the AC13-036 RFC system with C33-38B + G61MPV-36B-045.

COOLING CAPACITY - AC13-036 TXV System with [C33-38B + G61MPV-36B-070]

Table with columns for Entering Wet Bulb Temperature (63°F, 67°F, 71°F) and various capacity and ratio metrics for the AC13-036 TXV system with C33-38B + G61MPV-36B-070.

COOLING CAPACITY - AC13-036 RFC System with [C33-38B + G61MPV-36B-070]

Table with columns for Entering Wet Bulb Temperature (63°F, 67°F, 71°F) and various capacity and ratio metrics for the AC13-036 RFC system with C33-38B + G61MPV-36B-070.

COOLING CAPACITY - AC13-036 TXV System with [C33-43B + G60UHV-36B-090]

Table with columns for Entering Wet Bulb Temperature (63°F, 67°F, 71°F) and various capacity and ratio metrics for the AC13-036 TXV system with C33-43B + G60UHV-36B-090.

COOLING CAPACITY - AC13-036 RFC System with [C33-43B + G60UHV-36B-090]

Table with columns for Entering Wet Bulb Temperature (63°F, 67°F, 71°F) and various capacity and ratio metrics for the AC13-036 RFC system with C33-43B + G60UHV-36B-090.

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

AIR HANDLERS

Entering Wet Bulb Temperature	Total Air Volume		Outdoor Air Temperature Entering Outdoor Coil																							
			85°F (29°C)						95°F (35°C)						105°F (41°C)						115°F (46°C)					
	Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb				
				75°F 24°C	80°F 27°C	85°F 29°C				75°F 24°C	80°F 27°C	85°F 29°C				75°F 24°C	80°F 27°C	85°F 29°C				75°F 24°C	80°F 27°C	85°F 29°C		
cfm	L/s	kBtuh	kW				kBtuh	kW				kBtuh	kW				kBtuh	kW				kBtuh	kW			

COOLING CAPACITY - AC13-036 TXV System with

[CBX32MV-036]
[CBX40UHV-036]

63°F (17°C)	1090	515	34.0	10.0	2.25	.78	.93	1.00	32.6	9.6	2.51	.79	.95	1.00	31.0	9.1	2.81	.81	.97	1.00	29.6	8.7	3.14	.83	.99	1.00
	1225	580	34.8	10.2	2.25	.81	.96	1.00	33.4	9.8	2.52	.82	.98	1.00	31.8	9.3	2.82	.85	1.00	1.00	30.4	8.9	3.16	.87	1.00	1.00
	1380	650	35.8	10.5	2.27	.84	.99	1.00	34.2	10.0	2.54	.86	1.00	1.00	32.8	9.6	2.84	.88	1.00	1.00	31.4	9.2	3.17	.91	1.00	1.00
67°F (19°C)	1090	515	36.0	10.6	2.27	.61	.75	.89	34.6	10.1	2.54	.62	.77	.92	33.0	9.7	2.84	.63	.78	.94	31.4	9.2	3.17	.64	.81	.96
	1225	580	37.0	10.8	2.28	.63	.79	.93	35.4	10.4	2.55	.64	.80	.95	33.8	9.9	2.85	.65	.82	.97	32.0	9.4	3.19	.66	.84	1.00
	1380	650	37.6	11.0	2.29	.64	.82	.97	36.0	10.6	2.56	.66	.84	.99	34.4	10.1	2.86	.67	.86	1.00	32.6	9.6	3.19	.69	.88	1.00
71°F (22°C)	1090	515	38.0	11.1	2.30	.46	.60	.73	36.6	10.7	2.57	.46	.61	.75	35.0	10.3	2.87	.47	.62	.76	33.2	9.7	3.20	.47	.63	.78
	1225	580	39.0	11.4	2.31	.47	.62	.76	37.2	10.9	2.58	.47	.62	.78	35.6	10.4	2.88	.48	.64	.80	33.8	9.9	3.22	.48	.65	.82
	1380	650	39.5	11.6	2.32	.48	.64	.79	38.0	11.1	2.59	.48	.65	.81	36.2	10.6	2.89	.49	.66	.84	34.6	10.1	3.22	.49	.68	.86

COOLING CAPACITY - AC13-036 TXV System with

[CBX32MV-048]
[CBX40UHV-048]

63°F (17°C)	1205	570	36.2	10.6	2.27	.80	.96	1.00	34.8	10.2	2.54	.82	.98	1.00	33.2	9.7	2.84	.83	1.00	1.00	31.6	9.3	3.18	.86	1.00	1.00
	1375	650	37.4	11.0	2.29	.83	.99	1.00	35.8	10.5	2.56	.85	1.00	1.00	34.4	10.1	2.86	.88	1.00	1.00	32.8	9.6	3.20	.90	1.00	1.00
	1205	570	38.5	11.3	2.30	.62	.77	.92	36.8	10.8	2.57	.63	.79	.94	35.2	10.3	2.87	.64	.81	.97	33.4	9.8	3.20	.66	.83	.99
67°F (19°C)	1375	650	39.0	11.4	2.31	.64	.81	.97	37.6	11.0	2.58	.66	.83	.99	35.8	10.5	2.88	.67	.85	1.00	34.0	10.0	3.22	.68	.88	1.00
	1205	570	40.5	11.9	2.33	.46	.61	.75	39.0	11.4	2.60	.47	.62	.77	37.0	10.8	2.90	.47	.63	.79	35.4	10.4	3.24	.48	.64	.81
	1375	650	41.5	12.2	2.34	.47	.63	.79	39.5	11.6	2.61	.48	.64	.80	38.0	11.1	2.92	.48	.66	.83	36.0	10.6	3.25	.49	.67	.85

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section. Expanded rating tables are sorted by smallest to largest indoor unit model no.

UP-FLOW INDOOR COILS

Table with columns for Entering Wet Bulb Temperature, Total Air Volume (cfm, L/s), and Outdoor Air Temperature Entering Outdoor Coil (85°F, 95°F, 105°F, 115°F) with sub-columns for Total Cooling Capacity, Comp Motor kW Input, and Sensible To Total Ratio (S/T) Dry Bulb.

COOLING CAPACITY - AC13-042 TXV System with [C33-43B/C]

Table showing cooling capacity data for AC13-042 TXV System with C33-43B/C coils at 63°F, 67°F, and 71°F entering wet bulb temperatures.

COOLING CAPACITY - AC13-042 RFC System with [C33-43B/C]

Table showing cooling capacity data for AC13-042 RFC System with C33-43B/C coils at 63°F, 67°F, and 71°F entering wet bulb temperatures.

COOLING CAPACITY - AC13-042 TXV System with [C33-49C]

Table showing cooling capacity data for AC13-042 TXV System with C33-49C coils at 63°F, 67°F, and 71°F entering wet bulb temperatures.

COOLING CAPACITY - AC13-042 RFC System with [C33-49C]

Table showing cooling capacity data for AC13-042 RFC System with C33-49C coils at 63°F, 67°F, and 71°F entering wet bulb temperatures.

COOLING CAPACITY - AC13-042 TXV System with [C33-50/60C]

Table showing cooling capacity data for AC13-042 TXV System with C33-50/60C coils at 63°F, 67°F, and 71°F entering wet bulb temperatures.

COOLING CAPACITY - AC13-042 RFC System with [C33-50/60C]

Table showing cooling capacity data for AC13-042 RFC System with C33-50/60C coils at 63°F, 67°F, and 71°F entering wet bulb temperatures.

RATINGS

3.5 TON

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section. Expanded rating tables are sorted by smallest to largest indoor unit model no.

UP-FLOW INDOOR COIL WITH GAS FURNACES

Table with columns: Entering Wet Bulb Temperature, Total Air Volume (cfm, L/s), Outdoor Air Temperature Entering Outdoor Coil (85°F, 95°F, 105°F, 115°F), Total Cooling Capacity (kBTuh, kW), Comp Motor kW Input, Sensible To Total Ratio (S/T) Dry Bulb (75°F, 80°F, 85°F).

COOLING CAPACITY - AC13-042 RFC System with [C33-49C + G60UHV-60C-110]

Table with columns: Entering Wet Bulb Temperature (63°F, 67°F, 71°F) and 21 data points for cooling capacity and ratios at 85°F, 95°F, 105°F, and 115°F.

COOLING CAPACITY - AC13-042 RFC System with [C33-49C + G61MPV-60C-090]

Table with columns: Entering Wet Bulb Temperature (63°F, 67°F, 71°F) and 21 data points for cooling capacity and ratios at 85°F, 95°F, 105°F, and 115°F.

COOLING CAPACITY - AC13-042 TXV System with [C33-49C + G61MPV-60C-091]

Table with columns: Entering Wet Bulb Temperature (63°F, 67°F, 71°F) and 21 data points for cooling capacity and ratios at 85°F, 95°F, 105°F, and 115°F.

COOLING CAPACITY - AC13-042 RFC System with [C33-49C + G61MPV-60C-110]

Table with columns: Entering Wet Bulb Temperature (63°F, 67°F, 71°F) and 21 data points for cooling capacity and ratios at 85°F, 95°F, 105°F, and 115°F.

COOLING CAPACITY - AC13-042 TXV System with [C33-49C + G61MPV-60C-111]

Table with columns: Entering Wet Bulb Temperature (63°F, 67°F, 71°F) and 21 data points for cooling capacity and ratios at 85°F, 95°F, 105°F, and 115°F.

COOLING CAPACITY - AC13-042 TXV System with [C33-50/60C + G60UHV-60C-090]

Table with columns: Entering Wet Bulb Temperature (63°F, 67°F, 71°F) and 21 data points for cooling capacity and ratios at 85°F, 95°F, 105°F, and 115°F.

COOLING CAPACITY - AC13-042 RFC System with [C33-50/60C + G60UHV-60C-090]

Table with columns: Entering Wet Bulb Temperature (63°F, 67°F, 71°F) and 21 data points for cooling capacity and ratios at 85°F, 95°F, 105°F, and 115°F.

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

UP-FLOW INDOOR COILS

Entering Wet Bulb Temperature	Total Air Volume		Outdoor Air Temperature Entering Outdoor Coil																							
			85°F (29°C)						95°F (35°C)						105°F (41°C)						115°F (46°C)					
			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb		
cfm	L/s	kBtuh	kW	75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW	75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW	75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW	75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW	75°F 24°C	80°F 27°C	85°F 29°C

COOLING CAPACITY - AC13-048 TXV System with [C33-43B/C]

63°F (17°C)	1400	660	46.0	13.5	2.81	.76	.90	1.00	44.5	13.0	3.16	.78	.91	1.00	42.5	12.5	3.57	.79	.94	1.00	40.5	11.9	4.04	.81	.96	1.00
	1600	755	47.5	13.9	2.82	.79	.94	1.00	46.0	13.5	3.18	.81	.96	1.00	44.0	12.9	3.58	.82	.98	1.00	42.0	12.3	4.05	.84	1.00	1.00
	1800	850	48.5	14.2	2.84	.82	.98	1.00	47.0	13.8	3.19	.84	.99	1.00	45.0	13.2	3.60	.85	1.00	1.00	43.0	12.6	4.06	.88	1.00	1.00

COOLING CAPACITY - AC13-048 RFC System with [C33-43B/C]

63°F (17°C)	1400	660	45.0	13.2	2.81	.77	.91	1.00	43.5	12.7	3.15	.78	.93	1.00	42.0	12.3	3.55	.80	.95	1.00	40.0	11.7	4.01	.82	.97	1.00
	1600	755	46.5	13.6	2.83	.80	.95	1.00	45.0	13.2	3.17	.82	.97	1.00	43.0	12.6	3.56	.83	.99	1.00	41.0	12.0	4.02	.85	1.00	1.00
	1800	850	47.5	13.9	2.84	.83	.99	1.00	46.0	13.5	3.18	.85	1.00	1.00	44.0	12.9	3.58	.87	1.00	1.00	42.0	12.3	4.04	.89	1.00	1.00

COOLING CAPACITY - AC13-048 TXV System with [C33-48B]

63°F (17°C)	1400	660	45.5	13.3	2.82	.76	.89	1.00	44.0	12.9	3.17	.77	.91	1.00	42.0	12.3	3.58	.78	.93	1.00	40.0	11.7	4.06	.80	.95	1.00
	1600	755	48.0	14.1	2.84	.81	.96	1.00	46.0	13.5	3.20	.83	.98	1.00	44.0	12.9	3.61	.84	1.00	1.00	42.0	12.3	4.08	.87	1.00	1.00
	1800	850	48.0	14.1	2.84	.83	.99	1.00	46.0	13.5	3.18	.85	1.00	1.00	44.0	12.9	3.58	.87	1.00	1.00	42.0	12.3	4.04	.89	1.00	1.00

COOLING CAPACITY - AC13-048 TXV System with [C33-49C]

63°F (17°C)	1400	660	46.0	13.5	2.81	.76	.89	1.00	44.5	13.0	3.16	.77	.91	1.00	43.0	12.6	3.57	.79	.93	1.00	41.0	12.0	4.04	.81	.96	1.00
	1600	755	47.5	13.9	2.82	.79	.93	1.00	46.0	13.5	3.18	.80	.95	1.00	44.0	12.9	3.58	.82	.98	1.00	42.0	12.3	4.06	.84	1.00	1.00
	1800	850	49.0	14.4	2.84	.82	.97	1.00	47.0	13.8	3.19	.83	.99	1.00	45.0	13.3	3.60	.85	1.00	1.00	43.0	12.7	4.07	.88	1.00	1.00

COOLING CAPACITY - AC13-048 RFC System with [C33-49C]

63°F (17°C)	1450	685	46.0	13.5	2.82	.78	.92	1.00	44.5	13.0	3.16	.79	.94	1.00	42.5	12.5	3.56	.81	.96	1.00	40.5	11.9	4.02	.83	.99	1.00
	1600	755	47.0	13.8	2.83	.80	.95	1.00	45.5	13.3	3.17	.82	.97	1.00	43.5	12.7	3.57	.84	.99	1.00	41.5	12.2	4.03	.86	1.00	1.00
	1750	825	48.0	14.1	2.84	.83	.98	1.00	46.0	13.5	3.19	.84	1.00	1.00	44.5	13.0	3.58	.86	1.00	1.00	42.5	12.5	4.05	.89	1.00	1.00

COOLING CAPACITY - AC13-048 TXV System with [C33-50/60C]

63°F (17°C)	1400	660	46.0	13.5	2.81	.76	.89	1.00	44.5	13.0	3.16	.77	.91	1.00	42.5	12.5	3.57	.79	.93	1.00	40.5	11.9	4.03	.80	.96	1.00
	1600	755	47.5	13.9	2.82	.79	.93	1.00	45.5	13.3	3.17	.80	.95	1.00	44.0	12.9	3.58	.82	.97	1.00	41.5	12.2	4.05	.84	1.00	1.00
	1800	850	48.5	14.2	2.84	.82	.97	1.00	46.5	13.6	3.19	.83	.99	1.00	44.5	13.3	3.59	.85	1.00	1.00	42.5	12.5	4.06	.87	1.00	1.00

COOLING CAPACITY - AC13-048 RFC System with [C33-50/60C]

63°F (17°C)	1400	660	45.0	13.2	2.81	.77	.90	1.00	43.5	12.7	3.15	.78	.92	1.00	41.5	12.2	3.55	.79	.94	1.00	39.5	11.6	4.00	.81	.97	1.00
	1600	755	46.5	13.6	2.82	.80	.94	1.00	44.5	13.0	3.17	.81	.96	1.00	42.5	12.5	3.56	.83	.99	1.00	40.5	11.9	4.02	.85	1.00	1.00
	1800	850	47.5	13.9	2.84	.83	.98	1.00	45.5	13.3	3.18	.84	1.00	1.00	43.5	12.7	3.58	.86	1.00	1.00	42.0	12.3	4.04	.88	1.00	1.00

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

UP-FLOW INDOOR COIL WITH GAS FURNACES

Table with columns: Entering Wet Bulb Temperature, Total Air Volume (cfm, L/s), Outdoor Air Temperature Entering Outdoor Coil (85°F, 95°F, 105°F, 115°F), Total Cooling Capacity (kBtuh, kW), Comp Motor kW Input, Sensible To Total Ratio (S/T) Dry Bulb (75°F, 80°F, 85°F).

COOLING CAPACITY - AC13-048 TXV System with [C33-43C + G60UHV-60C-090]

Table with columns: Entering Wet Bulb Temperature (63°F, 67°F, 71°F), Total Air Volume (1460, 1635, 1845 cfm), and various capacity and ratio metrics for the AC13-048 TXV system.

COOLING CAPACITY - AC13-048 RFC System with [C33-43C + G60UHV-60C-090]

Table with columns: Entering Wet Bulb Temperature (63°F, 67°F, 71°F), Total Air Volume (1460, 1635, 1845 cfm), and various capacity and ratio metrics for the AC13-048 RFC system.

COOLING CAPACITY - AC13-048 TXV System with [C33-43C + G60UHV-60C-110]

Table with columns: Entering Wet Bulb Temperature (63°F, 67°F, 71°F), Total Air Volume (1395, 1600, 1780 cfm), and various capacity and ratio metrics for the AC13-048 TXV system.

COOLING CAPACITY - AC13-048 RFC System with [C33-43C + G60UHV-60C-110]

Table with columns: Entering Wet Bulb Temperature (63°F, 67°F, 71°F), Total Air Volume (1395, 1600, 1780 cfm), and various capacity and ratio metrics for the AC13-048 RFC system.

COOLING CAPACITY - AC13-048 RFC System with [C33-43C + G61MPV-60C-090]

Table with columns: Entering Wet Bulb Temperature (63°F, 67°F, 71°F), Total Air Volume (1380, 1605, 1755 cfm), and various capacity and ratio metrics for the AC13-048 RFC system.

COOLING CAPACITY - AC13-048 TXV System with [C33-43C + G61MPV-60C-091]

Table with columns: Entering Wet Bulb Temperature (63°F, 67°F, 71°F), Total Air Volume (1445, 1625, 1800 cfm), and various capacity and ratio metrics for the AC13-048 TXV system.

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

UP-FLOW INDOOR COIL WITH GAS FURNACES

Entering Wet Bulb Temperature	Total Air Volume		Outdoor Air Temperature Entering Outdoor Coil																						
			85°F (29°C)							95°F (35°C)						105°F (41°C)						115°F (46°C)			
			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb				Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb				Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb					
			kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW	75°F 24°C		80°F 27°C	85°F 29°C	kBtuh	kW	75°F 24°C	80°F 27°C		85°F 29°C	kBtuh	kW	75°F 24°C	80°F 27°C	85°F 29°C

COOLING CAPACITY - AC13-048 RFC System with [C33-43C + G61MPV-60C-110] [C33-43C + G71MPP-60C-110]

63°F (17°C)	1405	665	45.0	13.2	2.81	.77	.91	1.00	43.5	12.7	3.15	.78	.92	1.00	42.0	12.3	3.55	.79	.94	1.00	39.5	11.6	4.01	.81	.97	1.00
	1605	760	46.5	13.6	2.82	.80	.95	1.00	45.0	13.2	3.17	.81	.97	1.00	43.0	12.6	3.56	.83	.99	1.00	41.0	12.0	4.02	.85	1.00	1.00
	1790	845	47.5	13.9	2.84	.82	.98	1.00	45.5	13.3	3.18	.84	1.00	1.00	44.0	12.9	3.58	.86	1.00	1.00	42.0	12.3	4.04	.89	1.00	1.00

COOLING CAPACITY - AC13-048 TXV System with [C33-43C + G61MPV-60C-111]

63°F (17°C)	1400	660	45.5	13.3	2.79	.76	.90	1.00	44.0	12.9	3.13	.78	.92	1.00	42.0	12.3	3.53	.79	.94	1.00	40.0	11.7	3.99	.81	.97	1.00
	1605	760	47.0	13.8	2.81	.79	.94	1.00	45.0	13.2	3.15	.81	.96	1.00	43.5	12.7	3.55	.83	.99	1.00	41.0	12.0	4.01	.85	1.00	1.00
	1800	850	48.0	14.1	2.82	.83	.98	1.00	46.0	13.5	3.17	.84	1.00	1.00	44.0	12.9	3.56	.86	1.00	1.00	42.5	12.5	4.02	.88	1.00	1.00

COOLING CAPACITY - AC13-048 TXV System with [C33-48C + G60UHV-60C-090]

63°F (17°C)	1460	690	45.5	13.3	2.79	.76	.90	1.00	43.5	12.7	3.13	.78	.92	1.00	42.0	12.3	3.53	.79	.94	1.00	40.0	11.7	3.99	.81	.96	1.00
	1635	770	46.5	13.6	2.80	.79	.94	1.00	44.5	13.0	3.15	.80	.95	1.00	42.5	12.5	3.54	.82	.98	1.00	40.5	11.9	4.00	.84	1.00	1.00
	1795	845	47.0	13.8	2.81	.81	.97	1.00	45.5	13.3	3.16	.83	.98	1.00	43.5	12.7	3.55	.85	1.00	1.00	41.5	12.2	4.01	.87	1.00	1.00

COOLING CAPACITY - AC13-048 TXV System with [C33-48C + G60UHV-60C-110]

63°F (17°C)	1460	690	45.5	13.3	2.79	.77	.90	1.00	43.5	12.7	3.13	.78	.92	1.00	42.0	12.3	3.53	.79	.94	1.00	40.0	11.7	3.99	.81	.97	1.00
	1575	745	46.0	13.5	2.80	.78	.92	1.00	44.5	13.0	3.14	.79	.94	1.00	42.5	12.5	3.54	.81	.96	1.00	40.5	11.9	4.00	.83	.99	1.00
	1780	840	47.0	13.8	2.81	.81	.96	1.00	45.5	13.3	3.16	.83	.98	1.00	43.5	12.7	3.55	.84	1.00	1.00	41.5	12.2	4.01	.87	1.00	1.00

COOLING CAPACITY - AC13-048 TXV System with [C33-48C + G61MPV-60C-090] [C33-48C + G71MPP-60C-090]

63°F (17°C)	1440	680	45.5	13.3	2.79	.76	.90	1.00	43.5	12.7	3.13	.77	.92	1.00	41.5	12.2	3.53	.79	.94	1.00	40.0	11.7	3.99	.81	.96	1.00
	1560	735	46.0	13.5	2.80	.78	.92	1.00	44.0	12.9	3.14	.79	.94	1.00	42.5	12.5	3.54	.81	.96	1.00	40.5	11.9	4.00	.83	.99	1.00
	1755	830	47.0	13.8	2.81	.81	.96	1.00	45.0	13.2	3.16	.82	.98	1.00	43.5	12.7	3.55	.84	1.00	1.00	41.5	12.2	4.01	.86	1.00	1.00

COOLING CAPACITY - AC13-048 TXV System with [C33-48C + G61MPV-60C-110] [C33-48C + G71MPP-60C-110]

63°F (17°C)	1405	665	45.0	13.2	2.78	.76	.89	1.00	43.5	12.7	3.13	.77	.91	1.00	41.5	12.2	3.52	.78	.93	1.00	39.5	11.6	3.98	.80	.95	1.00
	1580	745	46.0	13.5	2.80	.78	.93	1.00	44.5	13.0	3.14	.80	.94	1.00	42.5	12.5	3.54	.81	.97	1.00	40.5	11.9	4.00	.83	.99	1.00
	1790	845	47.0	13.8	2.81	.81	.97	1.00	45.5	13.3	3.16	.83	.98	1.00	43.5	12.7	3.55	.85	1.00	1.00	41.5	12.2	4.01	.87	1.00	1.00

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

UP-FLOW INDOOR COIL WITH GAS FURNACES

Entering Wet Bulb Temperature	Total Air Volume		Outdoor Air Temperature Entering Outdoor Coil																							
			85°F (29°C)						95°F (35°C)						105°F (41°C)						115°F (46°C)					
			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb		
			kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C

COOLING CAPACITY - AC13-048 RFC System with [C33-50/60C + G61MPV-60C-090]

63°F (17°C)	1380	650	45.0	13.2	2.80	.76	.90	1.00	43.0	12.6	3.15	.77	.91	1.00	41.5	12.2	3.54	.79	.94	1.00	39.5	11.6	4.00	.80	.96	1.00
	1605	760	46.0	13.5	2.82	.79	.94	1.00	44.5	13.0	3.17	.81	.96	1.00	42.5	12.5	3.56	.82	.98	1.00	40.5	11.9	4.02	.85	1.00	1.00
	1755	830	47.0	13.8	2.83	.82	.97	1.00	45.5	13.3	3.18	.83	.99	1.00	43.5	12.7	3.57	.85	1.00	1.00	41.5	12.2	4.03	.87	1.00	1.00

COOLING CAPACITY - AC13-048 TXV System with [C33-50/60C + G61MPV-60C-091]

63°F (17°C)	1445	680	45.5	13.3	2.79	.77	.91	1.00	44.0	12.9	3.14	.78	.93	1.00	42.0	12.3	3.53	.80	.95	1.00	40.0	11.7	3.99	.81	.97	1.00
	1625	765	47.0	13.8	2.81	.80	.94	1.00	45.0	13.2	3.15	.81	.96	1.00	43.0	12.6	3.55	.83	.99	1.00	41.0	12.0	4.00	.88	1.00	1.00
	1800	850	48.0	14.1	2.82	.82	.98	1.00	46.0	13.5	3.16	.84	1.00	1.00	44.0	12.9	3.56	.86	1.00	1.00	42.0	12.3	4.02	.88	1.00	1.00

COOLING CAPACITY - AC13-048 RFC System with [C33-50/60C + G61MPV-60C-110]

63°F (17°C)	1405	665	45.0	13.2	2.80	.76	.90	1.00	43.5	12.7	3.15	.77	.92	1.00	41.5	12.2	3.55	.79	.94	1.00	39.5	11.6	4.00	.81	.96	1.00
	1605	760	46.5	13.6	2.82	.79	.94	1.00	44.5	13.0	3.17	.81	.96	1.00	42.5	12.5	3.56	.82	.98	1.00	40.5	11.9	4.02	.85	1.00	1.00
	1790	845	47.5	13.9	2.83	.82	.98	1.00	45.5	13.3	3.18	.84	1.00	1.00	43.5	12.7	3.57	.86	1.00	1.00	41.5	12.2	4.03	.87	1.00	1.00

COOLING CAPACITY - AC13-048 TXV System with [C33-50/60C + G61MPV-60C-111]

63°F (17°C)	1400	660	45.5	13.3	2.79	.76	.90	1.00	44.0	12.9	3.13	.77	.91	1.00	42.0	12.3	3.53	.79	.94	1.00	40.0	11.7	3.99	.81	.96	1.00
	1605	760	46.5	13.6	2.80	.79	.94	1.00	45.0	13.2	3.15	.81	.96	1.00	43.0	12.6	3.55	.82	.98	1.00	41.0	12.0	4.00	.84	1.00	1.00
	1800	850	48.0	14.1	2.82	.82	.98	1.00	46.0	13.5	3.16	.84	.99	1.00	44.0	12.9	3.56	.86	1.00	1.00	42.0	12.3	4.02	.88	1.00	1.00

COOLING CAPACITY - AC13-048 TXV System with [C33-60D + G60UHV-60D-135]

63°F (17°C)	1370	645	45.5	13.3	2.79	.76	.90	1.00	44.0	12.9	3.14	.77	.91	1.00	42.0	12.3	3.53	.79	.93	1.00	40.0	11.7	3.99	.81	.96	1.00
	1575	745	47.0	13.8	2.81	.79	.94	1.00	45.0	13.2	3.15	.81	.96	1.00	43.5	12.7	3.55	.82	.98	1.00	41.0	12.0	4.01	.84	1.00	1.00
	1745	825	48.0	14.1	2.82	.82	.97	1.00	46.0	13.5	3.17	.83	.99	1.00	44.0	12.9	3.56	.85	1.00	1.00	42.5	12.5	4.02	.88	1.00	1.00

COOLING CAPACITY - AC13-048 RFC System with [C33-60D + G60UHV-60D-135]

63°F (17°C)	1370	645	45.0	13.2	2.81	.76	.90	1.00	43.5	12.7	3.15	.78	.92	1.00	41.5	12.2	3.55	.79	.94	1.00	39.5	11.6	4.01	.81	.96	1.00
	1575	745	46.5	13.6	2.82	.79	.94	1.00	44.5	13.0	3.17	.81	.96	1.00	43.0	12.6	3.56	.83	.99	1.00	41.0	12.0	4.02	.85	1.00	1.00
	1745	825	47.5	13.9	2.84	.82	.98	1.00	45.5	13.3	3.18	.84	1.00	1.00	44.0	12.9	3.58	.86	1.00	1.00	42.0	12.3	4.04	.88	1.00	1.00

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

UP-FLOW INDOOR COIL WITH GAS FURNACES

Table with columns: Entering Wet Bulb Temperature, Total Air Volume (cfm, L/s), Outdoor Air Temperature Entering Outdoor Coil (85°F, 95°F, 105°F, 115°F), and Sensible To Total Ratio (S/T) Dry Bulb.

COOLING CAPACITY - AC13-048 RFC System with [C33-60D + G61MPV-60D-135] [C33-60D + G71MPP-60D-135]

Table showing cooling capacity for AC13-048 RFC system with G61MPV and G71MPP units at 63°F, 67°F, and 71°F.

COOLING CAPACITY - AC13-048 TXV System with [C33-62C + G60UHV-60C-090]

Table showing cooling capacity for AC13-048 TXV system with G60UHV units at 63°F, 67°F, and 71°F.

COOLING CAPACITY - AC13-048 RFC System with [C33-62C + G60UHV-60C-090]

Table showing cooling capacity for AC13-048 RFC system with G60UHV units at 63°F, 67°F, and 71°F.

COOLING CAPACITY - AC13-048 TXV System with [C33-62C + G60UHV-60C-110]

Table showing cooling capacity for AC13-048 TXV system with G60UHV units at 63°F, 67°F, and 71°F.

COOLING CAPACITY - AC13-048 RFC System with [C33-62C + G60UHV-60C-110]

Table showing cooling capacity for AC13-048 RFC system with G60UHV units at 63°F, 67°F, and 71°F.

COOLING CAPACITY - AC13-048 RFC System with [C33-62C + G61MPV-60C-090] [C33-62C + G71MPP-60C-090]

Table showing cooling capacity for AC13-048 RFC system with G61MPV and G71MPP units at 63°F, 67°F, and 71°F.

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

DOWN-FLOW INDOOR COILS

Table with columns for Entering Wet Bulb Temperature, Total Air Volume, Outdoor Air Temperature Entering Outdoor Coil, and various capacity and ratio metrics for three temperature ranges: 85°F (29°C), 95°F (35°C), and 105°F (41°C).

COOLING CAPACITY - AC13-048 TXV System with [CR33-50/60C-F]

Table showing cooling capacity and ratios for AC13-048 TXV system with CR33-50/60C-F coils at 63°F, 67°F, and 71°F entering wet bulb temperatures.

COOLING CAPACITY - AC13-048 TXV System with [CR33-60D-F]

Table showing cooling capacity and ratios for AC13-048 TXV system with CR33-60D-F coils at 63°F, 67°F, and 71°F entering wet bulb temperatures.

DOWN-FLOW INDOOR COILS WITH GAS FURNACES

COOLING CAPACITY - AC13-048 TXV System with [CR33-50/60C-F + G60DFV-60C-090]

Table showing cooling capacity and ratios for AC13-048 TXV system with gas furnaces and CR33-50/60C-F coils at 63°F, 67°F, and 71°F entering wet bulb temperatures.

COOLING CAPACITY - AC13-048 TXV System with [CR33-50/60C-F + G60DFV-60C-110]

Table showing cooling capacity and ratios for AC13-048 TXV system with gas furnaces and CR33-50/60C-F coils at 63°F, 67°F, and 71°F entering wet bulb temperatures.

COOLING CAPACITY - AC13-048 TXV System with [CR33-50/60C-F + G61MPV-60C-090] [CR33-50/60C-F + G71MPP-60C-090]

Table showing cooling capacity and ratios for AC13-048 TXV system with gas furnaces and CR33-50/60C-F coils at 63°F, 67°F, and 71°F entering wet bulb temperatures.

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

HORIZONTAL INDOOR COILS WITH GAS FURNACES

Table with columns for Entering Wet Bulb Temperature, Total Air Volume (cfm, L/s), Outdoor Air Temperature (85°F, 95°F, 105°F, 115°F), and various capacity and ratio metrics.

COOLING CAPACITY - AC13-048 TXV System with [CH33-43C-2F + G60UHV-60C-090]

Table showing cooling capacity data for AC13-048 TXV system with CH33-43C-2F + G60UHV-60C-090 refrigerant.

COOLING CAPACITY - AC13-048 TXV System with [CH33-43C-2F + G60UHV-60C-110]

Table showing cooling capacity data for AC13-048 TXV system with CH33-43C-2F + G60UHV-60C-110 refrigerant.

COOLING CAPACITY - AC13-048 TXV System with [CH33-43C-2F + G61MPV-60C-091]

Table showing cooling capacity data for AC13-048 TXV system with CH33-43C-2F + G61MPV-60C-091 refrigerant.

COOLING CAPACITY - AC13-048 TXV System with [CH33-43C-2F + G61MPV-60C-110]

Table showing cooling capacity data for AC13-048 TXV system with CH33-43C-2F + G61MPV-60C-110 refrigerant.

COOLING CAPACITY - AC13-048 TXV System with [CH33-43C-2F + G61MPV-60C-111]

Table showing cooling capacity data for AC13-048 TXV system with CH33-43C-2F + G61MPV-60C-111 refrigerant.

COOLING CAPACITY - AC13-048 TXV System with [CH33-48C-2F + G60UHV-60C-090]

Table showing cooling capacity data for AC13-048 TXV system with CH33-48C-2F + G60UHV-60C-090 refrigerant.

RATINGS

4 TON

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.

AIR HANDLERS

Entering Wet Bulb Temperature	Total Air Volume		Outdoor Air Temperature Entering Outdoor Coil																							
			85°F (29°C)						95°F (35°C)						105°F (41°C)						115°F (46°C)					
			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb		
			kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C

COOLING CAPACITY - AC13-048 TXV System with [CB30M-65]

63°F (17°C)	1400	660	46.5	13.6	2.80	.78	.92	1.00	44.5	13.0	3.15	.79	.94	1.00	42.5	12.5	3.54	.81	.96	1.00	40.5	11.9	4.00	.83	.98	1.00
	1600	755	47.5	13.9	2.82	.81	.96	1.00	46.0	13.5	3.16	.83	.98	1.00	44.0	12.9	3.56	.84	.99	1.00	42.0	12.3	4.02	.87	1.00	1.00
	1800	850	48.5	14.2	2.83	.84	.99	1.00	47.0	13.8	3.18	.86	1.00	1.00	45.0	13.2	3.58	.88	1.00	1.00	43.0	12.6	4.03	.91	1.00	1.00
67°F (19°C)	1400	660	48.5	14.2	2.83	.62	.75	.89	47.0	13.8	3.18	.63	.77	.90	45.0	13.2	3.57	.64	.78	.92	43.0	12.6	4.03	.65	.80	.95
	1600	755	50.0	14.7	2.85	.64	.79	.93	48.0	14.1	3.19	.65	.80	.95	46.0	13.5	3.59	.66	.82	.97	44.0	12.9	4.04	.67	.84	.99
	1800	850	51.0	14.9	2.86	.66	.82	.97	49.0	14.4	3.21	.67	.84	.98	47.0	13.8	3.60	.68	.86	1.00	45.0	13.2	4.06	.70	.88	1.00
71°F (22°C)	1400	660	51.0	14.9	2.87	.47	.61	.73	49.5	14.5	3.21	.48	.61	.74	47.5	13.9	3.61	.48	.62	.76	45.0	13.2	4.07	.49	.63	.78
	1600	755	52.5	15.4	2.89	.48	.63	.77	50.5	14.8	3.23	.49	.64	.78	48.5	14.2	3.63	.49	.65	.80	46.5	13.6	4.08	.50	.66	.82
	1800	850	54.0	15.8	2.90	.50	.65	.80	51.5	15.1	3.25	.50	.66	.82	49.5	14.5	3.64	.51	.67	.84	47.0	13.8	4.10	.51	.69	.86

COOLING CAPACITY - AC13-048 TXV System with [CBX32MV-048]

63°F (17°C)	1425	675	46.0	13.5	2.79	.78	.93	1.00	44.0	12.9	3.14	.80	.95	1.00	42.0	12.3	3.53	.82	.97	1.00	40.0	11.7	3.99	.84	.99	1.00
	1625	765	47.0	13.8	2.81	.82	.98	1.00	45.0	13.2	3.15	.84	.99	1.00	43.5	12.7	3.55	.86	1.00	1.00	41.5	12.2	4.01	.88	1.00	1.00
	1820	860	48.0	14.1	2.82	.86	1.00	1.00	46.5	13.6	3.17	.88	1.00	1.00	44.5	13.0	3.57	.90	1.00	1.00	43.0	12.6	4.03	.92	1.00	1.00
67°F (19°C)	1425	675	48.5	14.2	2.83	.62	.76	.90	46.5	13.6	3.17	.63	.78	.92	44.5	13.0	3.57	.64	.79	.94	42.5	12.5	4.03	.65	.81	.97
	1625	765	49.5	14.5	2.84	.64	.80	.95	47.5	13.9	3.19	.65	.81	.97	45.5	13.3	3.58	.66	.83	.99	43.5	12.7	4.04	.68	.86	1.00
	1820	860	50.5	14.8	2.86	.67	.83	.99	48.5	14.2	3.20	.68	.85	1.00	46.5	13.6	3.60	.69	.88	1.00	44.0	12.9	4.05	.71	.90	1.00
71°F (22°C)	1425	675	51.0	14.9	2.86	.47	.61	.74	49.0	14.4	3.21	.47	.61	.75	47.0	13.8	3.60	.48	.62	.77	45.0	13.2	4.06	.48	.64	.79
	1625	765	52.5	15.4	2.88	.48	.63	.78	50.5	14.8	3.22	.48	.64	.79	48.0	14.1	3.62	.49	.65	.81	46.0	13.5	4.08	.49	.67	.83
	1820	860	53.5	15.7	2.90	.49	.66	.81	51.5	15.1	3.24	.50	.67	.83	49.0	14.4	3.64	.50	.68	.85	46.5	13.6	4.09	.51	.70	.88

COOLING CAPACITY - AC13-048 TXV System with [CBX32MV-060]

63°F (17°C)	1425	675	46.5	13.6	2.80	.78	.92	1.00	44.5	13.0	3.15	.79	.94	1.00	42.5	12.5	3.54	.81	.96	1.00	40.5	11.9	4.00	.83	.98	1.00
	1625	765	47.5	13.9	2.82	.81	.96	1.00	46.0	13.5	3.16	.83	.98	1.00	44.0	12.9	3.56	.85	1.00	1.00	42.0	12.3	4.02	.87	1.00	1.00
	1820	860	49.0	14.4	2.83	.85	.99	1.00	47.0	13.8	3.18	.86	1.00	1.00	45.0	13.2	3.58	.88	1.00	1.00	43.0	12.7	4.03	.91	1.00	1.00
67°F (19°C)	1425	675	49.0	14.4	2.83	.62	.76	.89	47.0	13.8	3.18	.63	.77	.91	45.0	13.2	3.57	.64	.79	.93	43.0	12.6	4.03	.65	.80	.95
	1625	765	50.0	14.7	2.85	.64	.79	.93	48.0	14.1	3.19	.65	.81	.95	46.0	13.5	3.59	.66	.82	.97	44.0	12.9	4.04	.67	.84	.99
	1820	860	51.0	14.9	2.86	.66	.82	.97	49.5	14.5	3.21	.67	.84	.99	47.0	13.8	3.60	.69	.86	1.00	45.0	13.2	4.06	.70	.89	1.00
71°F (22°C)	1425	675	51.5	15.1	2.87	.47	.61	.73	49.5	14.5	3.21	.47	.61	.75	47.5	13.9	3.61	.48	.62	.76	45.5	13.3	4.07	.48	.63	.78
	1625	765	52.5	15.4	2.89	.48	.63	.77	51.0	14.9	3.23	.49	.64	.78	48.5	14.2	3.63	.49	.65	.80	46.5	13.6	4.08	.50	.66	.82
	1820	860	54.0	15.8	2.90	.50	.65	.80	52.0	15.2	3.25	.50	.66	.82	49.5	14.5	3.64	.51	.68	.84	47.0	13.8	4.10	.51	.69	.86

RATINGS

5 TON

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.
Expanded rating tables are sorted by smallest to largest indoor unit model no.

UP-FLOW INDOOR COIL WITH GAS FURNACES

Table with columns for Entering Wet Bulb Temperature, Total Air Volume (cfm, L/s), Outdoor Air Temperature Entering Outdoor Coil (85°F, 95°F, 105°F, 115°F), Total Cooling Capacity (kBTuh, kW), Comp Motor kW Input, and Sensible To Total Ratio (S/T) Dry Bulb (75°F, 80°F, 85°F).

COOLING CAPACITY - AC13-060 TXV System with [C33-49C + G61MPV-60C-110] [C33-49C + G71MPP-60C-110]

Table showing cooling capacity for AC13-060 TXV system with C33-49C and G61MPV/G71MPP coils. Rows include 63°F, 67°F, and 71°F wet bulb temperatures.

COOLING CAPACITY - AC13-060 RFC System with [C33-49C + G61MPV-60C-110] [C33-49C + G71MPP-60C-110]

Table showing cooling capacity for AC13-060 RFC system with C33-49C and G61MPV/G71MPP coils. Rows include 63°F, 67°F, and 71°F wet bulb temperatures.

COOLING CAPACITY - AC13-060 TXV System with [C33-60D + G60UHV-60D-135]

Table showing cooling capacity for AC13-060 TXV system with C33-60D and G60UHV coils. Rows include 63°F, 67°F, and 71°F wet bulb temperatures.

COOLING CAPACITY - AC13-060 RFC System with [C33-60D + G60UHV-60D-135]

Table showing cooling capacity for AC13-060 RFC system with C33-60D and G60UHV coils. Rows include 63°F, 67°F, and 71°F wet bulb temperatures.

COOLING CAPACITY - AC13-060 TXV System with [C33-60D + G61MPV-60D-135] [C33-60D + G71MPP-60D-135]

Table showing cooling capacity for AC13-060 TXV system with C33-60D and G61MPV/G71MPP coils. Rows include 63°F, 67°F, and 71°F wet bulb temperatures.

COOLING CAPACITY - AC13-060 RFC System with [C33-60D + G61MPV-60D-135] [C33-60D + G71MPP-60D-135]

Table showing cooling capacity for AC13-060 RFC system with C33-60D and G61MPV/G71MPP coils. Rows include 63°F, 67°F, and 71°F wet bulb temperatures.

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.
Expanded rating tables are sorted by smallest to largest indoor unit model no.

DOWN-FLOW INDOOR COILS

Entering Wet Bulb Temperature	Total Air Volume		Outdoor Air Temperature Entering Outdoor Coil																								
			85°F (29°C)						95°F (35°C)						105°F (41°C)						115°F (46°C)						
	Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb					
				75°F 24°C	80°F 27°C	85°F 29°C				75°F 24°C	80°F 27°C	85°F 29°C				75°F 24°C	80°F 27°C	85°F 29°C				75°F 24°C	80°F 27°C	85°F 29°C			
cfm	L/s	kBtuh	kW				kBtuh	kW				kBtuh	kW				kBtuh	kW				kBtuh	kW				
COOLING CAPACITY - AC13-060 TXV System with [CR33-60D-F]																											
63°F (17°C)	1480	700	55.5	16.3	3.71	.75	.88	.98	53.5	15.7	4.15	.76	.89	.99	51.5	15.1	4.67	.77	.91	1.00	49.0	14.4	5.27	.79	.93	1.00	
	1680	795	57.0	16.7	3.73	.77	.91	1.00	55.0	16.1	4.18	.79	.93	1.00	53.0	15.5	4.69	.80	.95	1.00	50.0	14.7	5.30	.82	.97	1.00	
	1880	885	58.5	17.1	3.75	.80	.95	1.00	56.5	16.6	4.20	.81	.96	1.00	54.0	15.8	4.72	.83	.97	1.00	51.5	15.1	5.32	.85	.99	1.00	
67°F (19°C)	1480	700	59.0	17.3	3.76	.60	.72	.84	57.0	16.7	4.21	.60	.73	.86	54.5	16.0	4.72	.61	.75	.88	52.0	15.2	5.32	.62	.76	.90	
	1680	795	60.5	17.7	3.78	.61	.75	.88	58.0	17.0	4.23	.62	.76	.90	56.0	16.4	4.75	.63	.78	.92	53.0	15.5	5.35	.64	.80	.94	
	1880	885	61.5	18.0	3.80	.63	.78	.91	59.5	17.4	4.25	.64	.79	.93	57.0	16.7	4.77	.65	.81	.95	54.5	16.0	5.37	.66	.83	.97	
71°F (22°C)	1480	700	62.0	18.2	3.81	.46	.58	.70	60.0	17.6	4.25	.46	.59	.71	57.5	16.9	4.77	.47	.60	.72	54.5	16.0	5.38	.47	.61	.74	
	1680	795	63.5	18.6	3.83	.47	.60	.73	61.5	18.0	4.28	.47	.61	.74	59.0	17.3	4.80	.47	.62	.75	56.0	16.4	5.41	.48	.63	.77	
	1880	885	65.0	19.0	3.85	.48	.62	.75	62.5	18.3	4.29	.48	.63	.77	60.0	17.6	4.81	.49	.64	.79	57.0	16.7	5.42	.49	.65	.81	

DOWN-FLOW INDOOR COILS WITH GAS FURNACES

COOLING CAPACITY - AC13-060 TXV System with [CR33-60D-F + G60DFV-60D-135]																											
63°F (17°C)	1670	790	57.0	16.7	3.73	.77	.91	1.00	55.0	16.1	4.17	.78	.92	1.00	52.5	15.4	4.69	.80	.94	1.00	50.0	14.7	5.29	.81	.96	1.00	
	1865	880	58.5	17.1	3.75	.79	.94	1.00	56.0	16.4	4.20	.81	.96	1.00	53.5	15.7	4.71	.83	.97	1.00	51.0	14.9	5.31	.85	.99	1.00	
	2050	970	59.5	17.4	3.77	.82	.97	1.00	57.0	16.7	4.21	.84	.98	1.00	54.5	16.0	4.73	.86	.99	1.00	52.0	15.2	5.34	.88	1.00	1.00	
67°F (19°C)	1670	790	60.5	17.7	3.79	.61	.74	.87	58.0	17.0	4.23	.62	.76	.89	55.5	16.3	4.75	.62	.77	.91	53.0	15.5	5.35	.64	.79	.94	
	1865	880	61.5	18.0	3.80	.63	.77	.91	59.5	17.4	4.25	.64	.79	.93	57.0	16.7	4.76	.65	.80	.95	54.0	15.8	5.37	.66	.82	.97	
	2050	970	62.5	18.3	3.82	.65	.80	.94	60.5	17.7	4.26	.65	.81	.96	58.0	17.0	4.78	.67	.83	.97	55.0	16.1	5.38	.68	.85	.99	
71°F (22°C)	1670	790	63.5	18.6	3.83	.46	.59	.72	61.0	17.9	4.28	.46	.60	.73	58.5	17.1	4.79	.47	.61	.75	56.0	16.4	5.40	.48	.62	.77	
	1865	880	65.0	19.0	3.85	.47	.62	.75	62.5	18.3	4.29	.47	.62	.76	60.0	17.6	4.81	.48	.63	.78	57.0	16.7	5.42	.49	.64	.80	
	2050	970	66.0	19.3	3.87	.48	.63	.77	63.5	18.6	4.31	.48	.64	.79	61.0	17.9	4.83	.49	.65	.81	58.0	17.0	5.44	.50	.67	.83	
COOLING CAPACITY - AC13-060 TXV System with [CR33-60D-F + G61MPV-60D-135]																											
63°F (17°C)	1565	740	56.5	16.6	3.72	.76	.89	.99	54.5	16.0	4.16	.77	.91	1.00	52.0	15.2	4.68	.78	.93	1.00	49.5	14.5	5.28	.80	.95	1.00	
	1780	840	58.0	17.0	3.74	.78	.93	1.00	55.5	16.3	4.19	.80	.95	1.00	53.0	15.5	4.70	.81	.96	1.00	50.5	14.8	5.30	.83	.98	1.00	
	1820	860	58.0	17.0	3.75	.79	.94	1.00	56.0	16.4	4.19	.81	.95	1.00	53.5	15.7	4.71	.82	.97	1.00	51.0	14.9	5.31	.84	.98	1.00	
67°F (19°C)	1565	740	59.5	17.4	3.77	.60	.73	.86	57.5	16.9	4.22	.61	.74	.88	55.0	16.1	4.73	.62	.76	.89	52.5	15.4	5.34	.63	.78	.92	
	1780	840	61.0	17.9	3.80	.62	.76	.90	59.0	17.3	4.24	.63	.77	.91	56.5	16.6	4.76	.64	.79	.93	53.5	15.7	5.36	.65	.81	.96	
	1820	860	61.5	18.0	3.80	.63	.77	.91	59.0	17.3	4.24	.64	.78	.92	56.5	16.6	4.76	.64	.80	.95	54.0	15.8	5.37	.66	.82	.96	
71°F (22°C)	1565	740	62.5	18.3	3.82	.46	.59	.71	60.5	17.7	4.26	.47	.60	.72	58.0	17.0	4.78	.47	.61	.73	55.5	16.3	5.39	.48	.62	.75	
	1780	840	64.0	18.8	3.84	.47	.61	.74	62.0	18.2	4.29	.47	.62	.75	59.5	17.4	4.80	.48	.63	.77	56.5	16.6	5.42	.49	.64	.79	
	1820	860	64.5	18.9	3.85	.48	.62	.75	62.0	18.2	4.30	.48	.62	.76	59.5	17.4	4.81	.48	.63	.78	57.0	16.7	5.42	.49	.65	.80	

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section. Expanded rating tables are sorted by smallest to largest indoor unit model no.

HORIZONTAL INDOOR COILS WITH GAS FURNACES

Table with columns for Entering Wet Bulb Temperature, Total Air Volume (cfm, L/s), Outdoor Air Temperature (85°F, 95°F, 105°F, 115°F), and Sensible To Total Ratio (S/T) Dry Bulb. Sub-columns include Total Cooling Capacity, Comp Motor kW Input, and Sensible To Total Ratio (S/T) Dry Bulb for each temperature.

COOLING CAPACITY - AC13-060 RFC System with [CH33-50/60C-2F + G60UHV-60C-110]

Table showing cooling capacity data for AC13-060 RFC System with CH33-50/60C-2F + G60UHV-60C-110. Rows represent entering wet bulb temperatures (63°F, 67°F, 71°F) and three capacity levels (1555, 1780, 1820).

COOLING CAPACITY - AC13-060 TXV System with [CH33-50/60C-2F + G61MPV-60C-110]

Table showing cooling capacity data for AC13-060 TXV System with CH33-50/60C-2F + G61MPV-60C-110. Rows represent entering wet bulb temperatures (63°F, 67°F, 71°F) and three capacity levels (1605, 1790, 1995).

COOLING CAPACITY - AC13-060 RFC System with [CH33-50/60C-2F + G61MPV-60C-110]

Table showing cooling capacity data for AC13-060 RFC System with CH33-50/60C-2F + G61MPV-60C-110. Rows represent entering wet bulb temperatures (63°F, 67°F, 71°F) and three capacity levels (1605, 1790, 1995).

COOLING CAPACITY - AC13-060 TXV System with [CH33-60D-2F + G60UHV-60D-135]

Table showing cooling capacity data for AC13-060 TXV System with CH33-60D-2F + G60UHV-60D-135. Rows represent entering wet bulb temperatures (63°F, 67°F, 71°F) and three capacity levels (1695, 1900, 1945).

COOLING CAPACITY - AC13-060 RFC System with [CH33-60D-2F + G60UHV-60D-135]

Table showing cooling capacity data for AC13-060 RFC System with CH33-60D-2F + G60UHV-60D-135. Rows represent entering wet bulb temperatures (63°F, 67°F, 71°F) and three capacity levels (1695, 1900, 1945).

COOLING CAPACITY - AC13-060 TXV System with [CH33-60D-2F + G61MPV-60D-135]

Table showing cooling capacity data for AC13-060 TXV System with CH33-60D-2F + G61MPV-60D-135. Rows represent entering wet bulb temperatures (63°F, 67°F, 71°F) and three capacity levels (1565, 1780, 1820).

RATINGS

5 TON

NOTES: For Temperatures and Capacities not shown in tables, see bulletin - Cooling Unit Rating Table Correction Factor Data in Miscellaneous Engineering Data section.
Expanded rating tables are sorted by smallest to largest indoor unit model no.

HORIZONTAL INDOOR COILS WITH GAS FURNACES

Entering Wet Bulb Temperature	Total Air Volume		Outdoor Air Temperature Entering Outdoor Coil																							
			85°F (29°C)						95°F (35°C)						105°F (41°C)						115°F (46°C)					
			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb			Total Cooling Capacity		Comp Motor kW Input	Sensible To Total Ratio (S/T) Dry Bulb		
			kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C	kBtuh	kW		75°F 24°C	80°F 27°C	85°F 29°C

COOLING CAPACITY - AC13-060 RFC System with [CH33-60D-2F + G61MPV-60D-135] [CH33-60D-2F + G71MPP-60D-135]

63°F (17°C)	1565	740	57.0	16.7	3.74	.74	.87	.99	54.5	16.0	4.19	.75	.88	1.00	52.5	15.4	4.70	.77	.90	1.00	49.5	14.5	5.30	.78	.93	1.00
	1780	840	58.5	17.1	3.76	.76	.90	1.00	56.0	16.4	4.21	.78	.92	1.00	53.5	15.7	4.72	.79	.94	1.00	51.0	14.9	5.32	.81	.97	1.00
	1820	860	58.5	17.1	3.77	.77	.91	1.00	56.5	16.6	4.21	.79	.93	1.00	54.0	15.8	4.73	.80	.95	1.00	51.0	14.9	5.33	.82	.98	1.00
67°F (19°C)	1565	740	60.5	17.7	3.79	.60	.72	.83	58.0	17.0	4.24	.60	.73	.85	55.5	16.3	4.76	.61	.74	.87	53.0	15.5	5.36	.62	.76	.89
	1780	840	62.0	18.2	3.82	.61	.74	.87	59.5	17.4	4.26	.62	.75	.89	57.0	16.7	4.78	.63	.77	.91	54.0	15.8	5.39	.64	.79	.93
	1820	860	62.0	18.2	3.83	.62	.75	.88	59.5	17.4	4.26	.62	.76	.90	57.0	16.7	4.79	.63	.78	.92	54.5	16.0	5.39	.65	.80	.95
71°F (22°C)	1565	740	63.5	18.6	3.85	.46	.58	.69	61.0	17.9	4.29	.47	.59	.70	58.5	17.1	4.81	.47	.60	.72	56.0	16.4	5.42	.47	.61	.73
	1780	840	65.0	19.0	3.87	.47	.59	.72	62.5	18.3	4.31	.47	.60	.73	60.0	17.6	4.83	.48	.61	.75	57.0	16.7	5.44	.48	.62	.76
	1820	860	65.0	19.0	3.87	.47	.60	.73	63.0	18.5	4.31	.48	.61	.74	60.5	17.7	4.84	.48	.62	.75	57.5	16.9	5.45	.49	.63	.77

COOLING CAPACITY - AC13-060 TXV System with [CH33-62D-2F + G60UHV-60D-135]

63°F (17°C)	1695	800	58.5	17.1	3.75	.75	.88	.99	56.0	16.4	4.20	.76	.89	1.00	54.0	15.8	4.71	.78	.91	1.00	51.0	14.9	5.31	.79	.94	1.00
	1900	895	60.0	17.6	3.78	.77	.91	1.00	57.5	16.9	4.22	.79	.93	1.00	55.0	16.1	4.73	.80	.95	1.00	52.5	15.4	5.34	.82	.98	1.00
	1945	920	60.0	17.6	3.78	.78	.92	1.00	58.0	17.0	4.22	.79	.94	1.00	55.5	16.3	4.74	.81	.96	1.00	52.5	15.4	5.34	.83	.98	1.00
67°F (19°C)	1695	800	61.5	18.0	3.80	.60	.73	.84	59.0	17.3	4.24	.61	.74	.86	56.5	16.6	4.76	.62	.75	.88	54.0	15.8	5.36	.63	.77	.90
	1900	895	63.0	18.5	3.83	.62	.75	.88	60.5	17.7	4.27	.62	.76	.90	58.0	17.0	4.78	.63	.78	.92	55.5	16.3	5.39	.65	.80	.94
	1945	920	63.5	18.6	3.83	.62	.75	.88	61.0	17.9	4.27	.63	.77	.90	58.5	17.1	4.79	.64	.78	.93	55.5	16.3	5.40	.65	.81	.95
71°F (22°C)	1695	800	64.5	18.9	3.85	.47	.59	.70	62.5	18.3	4.29	.47	.59	.71	60.0	17.6	4.81	.47	.60	.73	57.0	16.7	5.42	.48	.61	.75
	1900	895	66.0	19.3	3.87	.47	.60	.73	64.0	18.8	4.31	.48	.61	.74	61.0	17.9	4.83	.48	.62	.76	58.5	17.1	5.44	.49	.63	.77
	1945	920	67.0	19.6	3.88	.47	.61	.73	64.0	18.8	4.32	.48	.62	.75	61.5	18.0	4.84	.48	.63	.76	58.5	17.1	5.44	.49	.64	.78

COOLING CAPACITY - AC13-060 TXV System with [CH33-62D-2F + G61MPV-60D-135] [CH33-62D-2F + G71MPP-60D-135]

63°F (17°C)	1565	740	57.5	16.9	3.74	.74	.86	.98	55.5	16.3	4.18	.75	.88	.99	53.0	15.5	4.70	.76	.89	1.00	50.5	14.8	5.30	.78	.92	1.00
	1780	840	59.0	17.3	3.76	.76	.89	1.00	57.0	16.7	4.21	.77	.91	1.00	54.5	16.0	4.72	.79	.93	1.00	51.5	15.1	5.32	.81	.96	1.00
	1820	860	59.5	17.4	3.77	.77	.90	1.00	57.0	16.7	4.21	.78	.92	1.00	54.5	16.0	4.72	.80	.94	1.00	52.0	15.2	5.33	.81	.97	1.00
67°F (19°C)	1565	740	60.5	17.7	3.78	.60	.71	.83	58.0	17.0	4.23	.60	.73	.84	56.0	16.4	4.75	.61	.74	.86	53.5	15.7	5.35	.62	.75	.88
	1780	840	62.5	18.3	3.81	.61	.74	.86	60.0	17.6	4.25	.62	.75	.88	57.5	16.9	4.77	.63	.77	.90	54.5	16.0	5.37	.64	.78	.92
	1820	860	62.5	18.3	3.82	.62	.74	.87	60.0	17.6	4.26	.62	.76	.89	57.5	16.9	4.78	.63	.77	.91	55.0	16.1	5.38	.64	.79	.93
71°F (22°C)	1565	740	63.5	18.6	3.83	.47	.58	.69	61.5	18.0	4.28	.47	.59	.70	59.0	17.3	4.80	.47	.60	.72	56.5	16.6	5.41	.47	.60	.73
	1780	840	65.0	19.0	3.86	.47	.59	.71	63.0	18.5	4.30	.47	.60	.73	60.5	17.7	4.82	.48	.61	.74	57.5	16.9	5.43	.48	.62	.76
	1820	860	66.0	19.3	3.87	.48	.60	.72	63.5	18.6	4.31	.48	.61	.73	60.5	17.7	4.83	.48	.62	.75	58.0	17.0	5.43	.49	.63	.77

COOLING CAPACITY - AC13-060 RFC System with [CH33-62D-2F + G61MPV-60D-135] [CH33-62D-2F + G71MPP-60D-135]

63°F (17°C)	1565	740	57.0	16.7	3.75	.74	.86	.98	55.0	16.1	4.19	.75	.88	1.00	52.5	15.4	4.71	.77	.90	1.00	50.0	14.7	5.31	.78	.92	1.00
	1780	840	59.0	17.3	3.77	.76	.90	1.00	56.5	16.6	4.22	.78	.91	1.00	54.0	15.8	4.73	.79	.93	1.00	51.5	15.1	5.34	.81	.96	1.00
	1820	860	59.5	17.4	3.78	.77	.90	1.00	57.0	16.7	4.22	.78	.92	1.00	54.5	16.0	4.74	.80	.94	1.00	52.0	15.2	5.34	.82	.97	1.00
67°F (19°C)	1565	740	60.0	17.6	3.79	.60	.72	.83	58.0	17.0	4.24	.60	.73	.85	55.5	16.3	4.76	.61	.74	.87	53.0	15.5	5.36	.62	.76	.89
	1780	840	62.0	18.2	3.82	.61	.74	.86	59.5	17.4	4.26	.62	.75	.88	57.0	16.7	4.79	.63	.77	.90	54.5	16.0	5.39	.64	.79	.93
	1820	860	62.5	18.3	3.83	.62	.75	.87	60.0	17.6	4.27	.63	.76	.89	57.5	16.9	4.79	.63	.78	.91	55.0	16.1	5.40	.65	.80	.94
71°F (22°C)	1565	740	63.5	18.6	3.85	.47	.58	.69	61.0	17.9	4.29	.47	.59	.71	58.5	17.1	4.81	.47	.60	.72	56.0	16.4	5.42	.48	.61	.73
	1780	840	65.0	19.0	3.87	.47	.60	.72	63.0	18.5	4.31	.47	.60	.73	60.5	17.7	4.84	.48	.61	.75	57.5	16.9	5.44	.48	.63	.76
	1820	860	66.0	19.3	3.88	.47	.60	.73	63.0	18.5	4.32	.48	.61	.74	60.5	17.7	4.84	.48	.62	.75	58.0	17.0	5.45	.49	.63	.77

REVISIONS

Description of Change

Added ratings for CBX40UHV Air Handlers.



Visit us at www.lennox.com
For the latest technical information, www.lennoxdavenet.com
Contact us at 1-800-4-LENNOX

NOTE - Due to Lennox' ongoing commitment to quality, Specifications, Ratings and Dimensions subject to change without notice and without incurring liability. Improper installation, adjustment, alteration, service or maintenance can cause property damage or personal injury. Installation and service must be performed by a qualified installer and servicing agency.

©2009 Lennox Industries Inc.