

SUBMITTAL DATA - OUTDOOR UNIT MPC030S4M-1P

MULTI-ZONE MINI-SPLIT HEAT PUMP

| Job: | Engineer: |
|---------------------|---|
| Location: | Architect: |
| Schedule No.: | Date: |
| System Designation: | For: ☐ Reference ☐ Approval ☐ Review ☐ Construction |

FEATURES

Outdoor Unit: MPC036S4M-1P



- Defrost Control
- DC Inverter Control
- Base Pan Heater
- Crankcase Heater

Indoor Unit Options: Ducted OR Non-Ducted



Piping

| Line Set and Elevation Guidelines | |
|--|----------------|
| Maximum Number of Indoor Units/Zones | 3 |
| Liquid Line Set Diameter (in.) | (3) 1/4 |
| Gas Line Set Diameter (in.) | (3) 3/8 |
| Maximum Pipe Length ft. (m) | 197 ft. (60 m) |
| Maximum Line Set Length - Furthest Indoor Unit | 98 ft. (30 m) |
| Maximum Elevation - Outdoor Unit Below/Above Indoor Unit ft. (m) | 49 ft. (15m) |
| Pre-Charged (ft.) | 25 ft. |
| Additional Charge of Refrigerant (oz/ft.) | 0.16 |

PRODUCT WARRANTY

Compressor – Twelve year limited warranty*

All other covered components - Twelve year limited warranty*
*Product registration required

CERTIFIED WWW.ahridirectory.org





OPTIONAL ACCESSORIES

Non-Programmable Controller (M0STAT61Q-1) Programmable Controller (M0STAT64Q-2)



NOTE – Due to Lennox' ongoing commitment to quality, Specifications, Ratings, and Dimensions are subject to change without notice and without incurring liability. Improper installation, adjustment, alteration, service or maintenance can cause property damage or personal injury. Installation and service must be performed by a qualified installer and servicing agency.



SUBMITTAL DATA - OUTDOOR UNIT MPC030S4M-1P

MULTI-ZONE MINI-SPLIT HEAT PUMP

| OUTDOOR SPECIFICATION | NS | |
|---------------------------------------|------------|--------------|
| PERFORMANCE | | |
| Cooling Capacity (Btu/h) ¹ | Ducted | 28,000 |
| | Non-Ducted | 28,000 |
| EER | Ducted | 11.2 |
| | Non-Ducted | 12.5 |
| SEER | Ducted | 19.5 |
| | Non-Ducted | 23.8 |
| Heating Capacity (Btu/h) ¹ | Ducted | 28,000 |
| | Non-Ducted | 28,000 |
| HSPF | Ducted | 10.2 |
| | Non-Ducted | 10.5 |
| Outdoor Fan Total Air Volume | (CFM) | 2130 |
| Ambient Temperature Operatir | ng Range | |
| Cooling | | -13 - 122°F |
| Heating | | -13 - 86°F |
| ELECTRICAL DATA | | |
| Power Supply (V/Hz/Φ) | | 208-230/60/1 |
| Minimum Circuit Ampacity (A) | | 24.5 |
| Maximum Overcurrent Protecti | on (A) | 30.0 |
| Outdoor Fan Motor Output (W) | | 120 |
| Compressor RLA (A) | | 20 |
| No. of Compressors | | 1 |

| GENERAL DATA | | |
|------------------------------------|--------|---------------|
| Connection Ratio (%) | | 66% to 133% |
| Max. # of Indoor Units | | Up to 3 units |
| Sound Data (dBA) - Cooling/Heating | | 61/61 |
| Refrigerant type | | R-410A |
| Factory refrigerant charge | | 5 lbs. 11 oz. |
| DIMENSIONS | | |
| Unit Dimensions (in) | Height | 26-1/2 |
| | Width | 39 |
| | Depth | 13-3/4 |
| Shipping Weight (lb) | | 151 |
| Net Weight (lb) | | 140 |
| NOTES | | |

^{1.} Cooling and Heating Capacity data is rated at the following conditions:

Cooling: 80°FDB / 67°FWB Indoor, 95°FDB Outdoor Heating: 70°FDB Indoor, 47°FDB / 43°FWB Outdoor

Multi-Zone System Combinations

NOTE - For multi-zone systems, the total capacity of all indoor units must be 66% to 133% of the outdoor unit capacity.


| Outdoor Unit Model No. | Number of Zones | Indoor Unit Capacity | | | | | Nominal Cooling Capacity at Rated System Capacity (Btuh) | | | | | Nominal Heating Capacity at Rated System Capacity (Btuh) | | | | | |
|---------------------------|-----------------------|-------------------------|-----|------------|----------------|------------|---|--------|--------|----|----|---|--------|--------|----|----|--|
| | | #1 | #2 | #3 | #4 | #5 | #1 | #2 | #3 | #4 | #5 | #1 | #2 | #3 | #4 | #5 | |
| | | 6K | 12K | | | | 6,000 | 12,000 | | | | 6,500 | 12,900 | | | | |
| | | 6K | 18K | - - | | - - | 5,000 | 17,000 | | | | 6,300 | 18,900 | | | | |
| | | 9K | 9K | - - | | - - | 9,000 | 9,000 | | | | 9,700 | 9,700 | | | | |
| | 2 | 9K | 12K | - - | | - - | 8,000 | 11,000 | | | | 9,700 | 12,900 | | | | |
| | 2 | 9K | 18K | | | | 8,000 | 16,000 | | | | 9,200 | 18,300 | | | | |
| | | 12K | 12K | | | | 11,000 | 11,000 | | | | 12,600 | 12,600 | | | | |
| | | 12K | 18K | | | | 10,000 | 15,000 | | | | 11,600 | 17,400 | | | | |
| | | 18K | 18K | | | | 14,000 | 14,000 | | | | 14,800 | 14,800 | | | | |
| | 3 | 6K | 6K | 6K | - - | | 7,000 | 7,000 | 7,000 | | | 8,500 | 8,500 | 8,500 | | | |
| | | 6K | 6K | 9K | | | 7,000 | 7,000 | 10,000 | | | 7,700 | 7,700 | 11,500 | | | |
| MPC030S4M | | 6K | 6K | 12K | | | 6,000 | 6,000 | 13,000 | | | 7,000 | 7,000 | 13,900 | | | |
| WIF CU3U34WI | | 6K | 6K | 18K | | | 6,000 | 6,000 | 17,000 | | | 5,900 | 5,900 | 17,500 | | | |
| | | 6K | 9K | 9K | - - | | 6,000 | 10,000 | 10,000 | | | 7,000 | 10,500 | 10,500 | | | |
| | | 6K | 9K | 12K | | | 6,000 | 9,000 | 12,000 | | | 6,400 | 9,500 | 12,700 | | | |
| | | 6K | 9K | 18K | - - | | 5,000 | 8,000 | 16,000 | | | 5,400 | 8,100 | 16,100 | | | |
| | | 6K | 12K | 12K | | | 6,000 | 11,000 | 11,000 | | | 5,900 | 11,700 | 11,700 | | | |
| | | 6K | 12K | 18K | - - | | 5,000 | 10,000 | 15,000 | | | 5,000 | 10,000 | 15,000 | | | |
| | | 9K | 9K | 9K | - - | | 9,000 | 9,000 | 9,000 | | | 9,500 | 9,500 | 9,500 | | | |
| | | 9K | 9K | 12K | - - | | 9,000 | 9,000 | 11,000 | | | 8,800 | 8,800 | 11,700 | | | |
| | | 9K | 9K | 18K | | | 7,000 | 7,000 | 15,000 | | | 7,500 | 7,500 | 15,000 | | | |
| | | 9K | 12K | 12K | - - | | 8,000 | 11,000 | 11,000 | | | 8,100 | 10,800 | 10,800 | | | |
| | | 12K | 12K | 12K | - - | | 10,000 | 10,000 | 10,000 | | | 10,000 | 10,000 | 10,000 | | | |





SUBMITTAL DATA - OUTDOOR UNIT MPC030S4M-1P

MULTI-ZONE MINI-SPLIT HEAT PUMP

OUTDOOR DIMENSIONAL DRAWINGS - INCHES (MM)







NOTE – Due to Lennox' ongoing commitment to quality, Specifications, Ratings, and Dimensions are subject to change without notice and without incurring liability. Improper installation, adjustment, alteration, service or maintenance can cause property damage or personal injury. Installation and service must be performed by a qualified installer and servicing agency.