

## SUBMITTAL DATA - OUTDOOR UNIT **VPB168L4M-3G**

## VPB096L4M-3G + VPB072L4M-3G

## **VRF Heat Pump**

Job:	Engineer:			
Location:	Architect:			
Schedule No.:	Location:			
System Designation:	Date:			
leat Pump Outdoor Unit	For: Reference	Approval	Review	Construction

#### **FEATURES**

- Split coil heat exchanger
- · Dual hinged electrical boxes for ease of
- · High-efficiency vapor injection inverter compressor
- · Intelligent Duty Cycle operation
- · Night Silent operation
- · Hinged service doors
- · Built-in service console

- Built-in base pan heater
- · Heating Operation down to -22F
- · Low Ambient Cooling down to -10F w/ kit

#### WARRANTY

- · Compressor 10-year limited warranty
- All other components 10-year limited warranty \*See warranty for details

SPECIFICATIONS		
PERFORMANCE		
Cooling Capacity <sup>1</sup> (Btu/h)	Nominal	168,000
(=)	Rated <sup>2</sup>	160,000
EER	Ducted	11.5
	Non-Ducted	12.1
IEER	Ducted	23.1
	Non-Ducted	22.9
Heating Capacity¹ (Btu/h)	Nominal	189,000
	Rated <sup>2</sup>	180,000
COP47	Ducted	3.76
	Non-Ducted	4.08
COP17	Ducted	2.57
	Non-Ducted	2 66

ELECTRICAL DATA	
Power Supply (Volts/Phase/Hertz)	460/3/60
Minimum Circuit Ampacity (A)	39.5+27.5
Maximum Overcurrent Protection (A)	40+30
Compressor RLA (A)	15.5+15.5+19.6
Number of Compressors	2+1
Outdoor Fan Power Input (W)	1200/1200+750/850
Outdoor Fan FLA (A)	2.2/2.4+1.4/1.6
CENEDAL DATA	

GENERAL DATA	
Connection Ratio	50% to 130%
Maximum Number of Indoor Units	29
Refrigerant Type	R-410A
Factory Refrigerant Charge (each unit)	23.8 lbs.

#### **NOTES**

- Cooling and Heating capacity data is rated at the following
  - Cooling: 80°FDB / 67°FWB Indoor, 95°FDB Outdoor
  - Heating: 70°FDB Indoor, 47°FDB / 43°FWB Outdoor.
- Complies with AHRI 1230-2014 testing standards
- Operating Voltage Range 410V to 525V
- To achieve cooling lower than 5°F a Low ambient hood must be installed. This is purchased as an accessory.
- A local 115V power outlet is available as an accessory to provide local power for maintenance.



DIMENSIONS		VPB096	VPB072				
Unit	Height	72	64-3/8				
Dimensions (in)	Width	68-1/2	52-3/4				
	Depth	32-5/8	31-1/2				
Main System Piping (in)							
Liquid Pipe Connection	1	3/4	5/8				
Gas Pipe Connection	1-1/4	1					
Balancing Pipework between Modules (in)							
L.P. Gas Balance Pipe Connection		1-1/4	1-1/8				
H.P. Gas Balance Pipe Connection	3/4	3/4					
Oil Balance Pipe Conn	ection	5/16	5/16				
Unit Net Weight (lb)		1076	800				








## SUBMITTAL DATA - OUTDOOR UNIT VPB168L4M-3G VPB096L4M-3G + VPB072L4M-3G VRF Heat Pump

### DIMENSIONAL DRAWINGS - INCHES (MM)

**VPB096** 

CORNER WEIGHTS									
Model No.	A	AA		BB		CC		DD	
	lbs.	kg	lbs.	kg	lbs.	kg	lbs.	kg	
096, 120L4M-3Y	171	78	262	119	327	148	318	144	
096, 120L4M-3G	173	78	266	121	332	151	323	147	






## SUBMITTAL DATA - OUTDOOR UNIT VPB168L4M-3G VPB096L4M-3G + VPB072L4M-3G

# VRF Heat Pump

## DIMENSIONAL DRAWINGS - INCHES (MM)

**VPB072** 

CORNER WEIGHTS								
Model No.	AA		ВВ		CC		DD	
	lbs.	kg	lbs.	kg	lbs.	kg	lbs.	kg
072L4M-3Y	118	54	198	90	206	93	245	111
072L4M-3G	124	56	207	94	215	98	256	116



NOTE – Due to Lennox' ongoing commitment to quality, Specifications, Ratings and Dimensions subject to change without notice and without incurring liability. Improper installation, adjustment, alteration, service or maintenance can cause property damage or personal injury.

Installation and service must be performed by a qualified installer and servicing agency.


495869 (202006) ©2020 Lennox Industries Inc.



# SUBMITTAL DATA - OUTDOOR UNIT VPB168L4M-3G VPB096L4M-3G + VPB072L4M-3G VRF Heat Pump


#### **MULTI-MODULE INFORMATION**

#### **Multi-Module Dimensions**



**NOTE** - All the outdoor units manifolded together should be installed at the same elevation.

#### **Multi-Module Power**



See page 1 for electrical data.

Total system MCA is calcuated by adding the MCA value of each module together to get the total system MCA.

Total system MOP is calcuated by adding the MOP value of each module together to get the total system MCA.