

SUBMITTAL DATA - OUTDOOR UNIT

VRB432H4M-3Y

VRB168H4M-3Y + VRB144H4M-3Y+ VRB120H4M-3Y

VRF Heat Recovery

Job: _____
 Location: _____
 Schedule No.: _____
 System Designation: _____

Engineer: _____
 Architect: _____
 Location: _____
 Date: _____

Heat Recovery Outdoor Unit

For: Reference Approval Review Construction

FEATURES

- Split coil heat exchanger
- Dual hinged electrical boxes for ease of maintenance
- High-efficiency vapor injection inverter compressors
- Intelligent Duty Cycle operation
- Night Silent operation
- Hinged service doors
- Built-in service console
- Built-in base pan heater
- Low Ambient Cooling

WARRANTY

- Compressor - 10-year limited warranty
 - All other components - 10-year limited warranty
- *See warranty for details

SPECIFICATIONS

PERFORMANCE

Cooling Capacity ¹ (Btu/h)	Nominal	432,000
	Rated ²	416,000
EER	Ducted	9.5
	Non-Ducted	9.5
IEER	Ducted	18.4
	Non-Ducted	18.3
Simultaneous Heating and Cooling Efficiency (SCHE)	Ducted	22.2
	Non-Ducted	22.5
Heating Capacity ¹ (Btu/h)		460,000
COP47	Ducted	3.28
	Non-Ducted	3.2
COP17	Ducted	2.23
	Non-Ducted	2.11

ELECTRICAL DATA

Power Supply (Volts/Phase/Hertz)	208-230/3/60
Minimum Circuit Ampacity (A)	(2) 69.5 + 54
Maximum Overcurrent Protection (A)	(2) 80 + 60
Compressor RLA (A)	(2) 27.2/27.2 + 38.3
Number of Compressors	(2) 2 + 1
Outdoor Fan Power Input (W)	(2) 1200/1200 + 780/890

GENERAL DATA

Connection Ratio	50% to 130%
Maximum Number of Indoor Units	64
Refrigerant Type	R-410A
Factory Refrigerant Charge (each unit)	23.8 lbs.

NOTES

- Cooling and Heating capacity data is rated at the following conditions:
 Cooling: 80°FDB / 67°FWB Indoor, 95°FDB Outdoor
 Heating: 70°FDB Indoor, 47°FDB / 43°FWB Outdoor
- Complies with AHRI 1230-2014 testing standards
- Operating Voltage Range 175V to 263V
- To achieve cooling lower than 5°F a Low ambient hood must be installed. This is purchased as an accessory.
- A local 115V power outlet is available as an accessory to provide local power for maintenance.



DIMENSIONS

	VRB168	VRB144	VRB120
Unit Height	72	72	64-3/8
Unit Width	68-1/2	68-1/2	52-3/4
Unit Depth	32-5/8	32-5/8	31-1/2

Main System Piping (in)

	VRB168	VRB144	VRB120
Liquid Pipe Connection	3/4	3/4	5/8
High Pressure Gas Pipe	1-3/8	1-3/8	1-1/8
Low Pressure Gas Pipe	1-3/8	1-3/8	1-1/8

Balancing Pipework between Modules (in)

	VRB168	VRB144	VRB120
Gas Balance Pipe Connection	3/4	3/4	3/4
Oil Balance Pipe Connection	1/4	1/4	1/4
Unit Net Weight (lb)	1118	1118	794




SUBMITTAL DATA - OUTDOOR UNIT
VRB432H4M-3Y
VRB168H4M-3Y + VRB144H4M-3Y+ VRB120H4M-3Y
VRF Heat Recovery

DIMENSIONAL DRAWINGS - INCHES (MM)

VRB168 & VRB144

CORNER WEIGHTS								CENTER OF GRAVITY			
AA		BB		CC		DD		EE		FF	
lbs.	kg	lbs.	kg	lbs.	kg	lbs.	kg	in.	mm	in.	mm
172	78	264	120	330	150	321	146	37-3/4	953	12	305




NOTE - Due to Lennox' ongoing commitment to quality, Specifications, Ratings and Dimensions subject to change without notice and without incurring liability. Improper installation, adjustment, alteration, service or maintenance can cause property damage or personal injury. Installation and service must be performed by a qualified installer and servicing agency. 495778 (2003) ©2020 Lennox Industries Inc.

SUBMITTAL DATA - OUTDOOR UNIT
VRB432H4M-3Y
VRB168H4M-3Y + VRB144H4M-3Y+ VRB120H4M-3Y
VRF Heat Recovery

DIMENSIONAL DRAWINGS - INCHES (MM)

VRB120


CORNER WEIGHTS								CENTER OF GRAVITY			
AA		BB		CC		DD		EE		FF	
lbs.	kg	lbs.	kg	lbs.	kg	lbs.	kg	in.	mm	in.	mm
121	55	203	92	211	96	251	114	27-3/4	705	12-1/4	311



NOTE - Due to Lennox' ongoing commitment to quality, Specifications, Ratings and Dimensions subject to change without notice and without incurring liability. Improper installation, adjustment, alteration, service or maintenance can cause property damage or personal injury. Installation and service must be performed by a qualified installer and servicing agency. 495778 (202008) ©2020 Lennox Industries Inc.

MULTI-MODULE INFORMATION


Multi-Module Dimensions



NOTE - All the outdoor units manifolded together should be installed at the same elevation.

TOP VIEW

Multi-Module Power



See page 1 for electrical data.

Total system MCA is calculated by adding the MCA value of each module together to get the total system MCA.

Total system MOP is calculated by adding the MOP value of each module together to get the total system MCA.